NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED OCT 20 1967 STATE ENGINEER

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

POLK 1000

State Well No. 6/3W-7

State Permit No. G6912

(1) OWNER:
Name LLOYD RAY
Address LONE STAR RD.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 28 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 22 ft. below land surface Date 8-30-67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
AIR " " "
~~Bailer~~ test 50 gal./min. with 128 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used CONCRETE
Depth of seal 27 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County POLK Driller's well number
¼ ¼ Section 7 T. 6S R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 216 ft. Depth of completed well 216 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	1	
Brown - CLAY	1	5	
" - WEATHERED ROCK	5	28	
BLACK - BASALT "	28	30	
" - " WEATHERED	30	40	
" - " BROKEN	40	44	
RED - ROCK Completely WEATHERED	44	50	
BROWN - WEATHERED ROCK	50	59	
BLACK - BASALT ROCK	59	83	
PARTLY BROKEN	~~83~~	~~155~~	
BLACK - BASALT ROCK	83	155	
" - " HONEYCOMB	155	165	
" - " WEATHERED	165	185	
" - " BROKEN	185	190	
" - " WEATHERED	190	191	
" - " ROCK	191	216	

Work started 8-28-67 19 Completed 8-30-67 19
Date well drilling machine moved off of well 8-30-67 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Geo. Rubinson Date 9-1-67 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 64

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Miller-Rubinson & West
(Person, firm or corporation) (Type or print)
Address 5545 Joseph St. S.E. Salem
[Signed] Harlan R. Miller
(Water Well Contractor)
Contractor's License No. 37 Date 9-1-67, 19

(USE ADDITIONAL SHEETS IF NECESSARY)