NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT. VE PATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No.  $65/3\omega-29$ State Permit No.

SALEM, OREGON 97310 within 30 days from the date JANA 1979 WATER RESOURCES DEPT. write above this line) of well completion.

1) OWNER: SALEM, OREGON	(10) LOCATION OF WELL:	
• 1	County Polk Driller's well number 2186	
ame KXXXX Robert Hines ddress 6005 Wallase RD. NW		. 3W W.M.
Salem, Oregon 97304	Bearing and distance from section or subdivision	
2) TYPE OF WORK (check):	Bearing and distance from section of subdivision correct	
rew Well X Deepening □ Reconditioning □ Abandon □		
abandonment, describe material and procedure in Item 12.	(11) WAMED I EVEL Completed we	11
	(11) WATER LEVEL: Completed well.	
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 74 ft.  Static level 58 ft. below land surface. Date 10/31/78	
otary X Driven Domestic Industrial Municipal Domestic	Static level 58 ft. below land su	face. Date 10/31/70
ug 🗌 Bored 🗍 Irrigation 🔀 Test Well 🗍 Other 📋	Artesian pressure lbs. per square inch. Date	
CASING INSTALLED: Threaded   Welded M 10 "Diam from top ft to 125 ft Gage 250 ft Gage PERFORATIONS: Perforated? MY Yes   No.	(12) WELL LOG: Diameter of well below casing  Depth drilled 138 ft. Depth of completed well 125 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
Type of perforator used Mills Knife	MATERIAL	From To SWL
2/0 21.	Topsoil	0 2
7.16	Brown Clay	2 41
perforations from OS ft. to 110 ft.	Gray Clay	41 /4
perforations from ft. to ft.	Cemented Black Sand and	
periorations from	Gravel	74   116
7) SCREENS: Well screen installed?   Yes XNo	Blue Clay	116   138
Manufacturer's Name		
Type Model No		
Diam Slot size Set from ft. to ft.		
Diam Slot size Set from ft. to ft.	. = :	
8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? 🛛 Yes 🗌 No If yes, by whom? driller		
gal./min. with 39 ft. drawdown after 3 hrs.		
" "		
" " " "	7	
Bailer test gal./min. with ft. drawdown after hrs.	7	
Artesian flow g.p.m.		
perature of water Depth artesian flow encounteredft.	Work started 10/26/78 19 Completed	10/31/78 19
perature of water Depth arcesian now encountered	Date well drilling machine moved off of well	10/31/78 19
(9) CONSTRUCTION:		10
Well seal—Material used Portland Cement  Well sealed from land surface to 19  Diameter of well bore to bottom of seal 14  Diameter of well bore below seal 10  Number of sacks of cement used in well seal 12  How was cement grout placed? Poured in from the top	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.  [Signed] Date 10/31/789  Drilling Machine Operator's License No	
How was cement grout placed?		
	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was a drive shoe used? X Yes No Plugs Size: location ft.	Name Willamette Drilling Co.  (Person firm or corporation) (Type or print)	
Did any strata contain unusable water?   Yes X No	Address 1450 Barnick Rd. NE Salem, OR 97303	
Type of water? depth of strata	Address 1 100 Data 110 110 110 110 110 110 110 110 110 11	
Method of sealing strata off	[Signed] Dallas D Security (Water Well Contractor)	
Was well gravel packed? [] Yes X No Size of gravel:		
Gravel placed from ft. to ft.	Contractor's License No. 561 Date	, 19