

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 (Please type or print) within 30 days from the date of well completion.

STATE OF OREGON (Do not write above this line)

Polk 1234

State Well No. 6/4w-25ddd

STATE ENGINEER SALEM OREGON

G-5958

State Permit No.

(1) OWNER:

Name GORDON WALKER Address Rt. 1 - Box 752 Salem

(11) LOCATION OF WELL:

County polk Driller's well number 1/4 Section 25 T. 6S R. 4E W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [] Deepening [x] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(6) CASING INSTALLED:

12" Diam. from 87 ft. to 118 ft. Gage 250. Threaded [] Welded [x]

(12) WELL LOG:

Diameter of well below casing 12. Depth drilled 200 ft. Depth of completed well 150 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: COARSE GRAVEL + BLUE CLAY, BLACK-BASALT, HARD LAYER OF ROCK, UNCOMPACTED-BASALT, BROWN, RED + BLACK IN COLOR, BROWN-CLAY STONE (VERY STICKY), BLUE-GRAY-SEDIMENTARY ROCK, etc.

More water filled by carving below end of casing at 118 ft

(7) PERFORATIONS:

Perforated? [x] Yes [] No. Type of perforator used Annular Size of perforations 1/2 in. by 2 in. 200 perforations from 75 ft. to 95 ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 26 ft. below land surface Date 10-13-68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Stettler Yield: 145 gal./min. with 92 ft. drawdown after 3 hrs.

(10) CONSTRUCTION:

Well seal-Material used Depth of seal Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [] Yes [] No Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [] No Size of gravel: Gravel placed from ft. to ft.

Work started 10-3-1968 Completed 10-15-1968 Date well drilling machine moved off of well 10-24-1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Marion West (Drilling Machine Operator) Date 10-16-1968

Drilling Machine Operator's License No. 188

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME William Robinson & West (Person, firm or corporation) (Type or print)

Address 5545 Joseph St. S.E. Salem

[Signed] William Robinson (Water Well Contractor)

Contractor's License No. 37 Date 10-16-1968