

RECEIVED

NOTICE TO WATER WELL CONTRACTOR MAY 17 1967

The original and first copy of this report are to be filed with the

STATE ENGINEER WATERWELL REPORT

STATE ENGINEER, SALEM, OREGON STATE OF OREGON (Please type or print)

Perk 1261

State Well No. 6/46-36 State Permit No.

(1) OWNER:

Name MILLER - Robin Seal & West Address 5545 Joseph St. S.E. Salem Ore

(2) LOCATION OF WELL:

County PERK Driller's well number 36 T. 6, S. R. 4, W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [checked] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [checked] Rotary [] Driven [] Cable [checked] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from 71 ft. to 193 ft. Gage 250 8" Diam. from 186 ft. to 343 ft. Gage 250

(7) PERFORATIONS:

Type of perforator used TORCH Perforated? [checked] Yes [] No Size of perforations 5/8 in. by 6 in. 240 perforations from 195 ft. to 340 ft.

(8) SCREENS:

Well screen installed? [] Yes [checked] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal 1/4" CRUSHED ROCK Depth of seal 6.5 ft. Was a packer used? NO Diameter of well bore to bottom of seal 18 in. Were any loose strata cemented off? [] Yes [checked] No Depth 10" Was a drive shoe used? [checked] Yes [] No Was well gravel packed? [] Yes [checked] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [checked] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 87 ft. below land surface Date 2-18-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [checked] Yes [] No If yes, by whom? WEST Yield: 440 gal./min. with 125 ft. drawdown after 5 hrs.

(12) WELL LOG:

Diameter of well below casing 8 Depth drilled 400 ft. Depth of completed well 400 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: RED - CLAY STONIE 0 40, BROWN - PARTLY DECOMPOSED ROCK 40 80, BRACKEN - DECOMPOSED ROCK 80 365, BLUE - CLAY STONIE 365 400

Work started 1-4-67 Completed 2-18-67 Date well drilling machine moved off of well 2-18-67

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MILLER - ROBINSON & WEST (Person, firm or corporation) (Type or print) Address 5545 Joseph St. S.E. Salem Drilling Machine Operator's License No. 188 [Signed] Harold R. Miller (Water Well Contractor) Contractor's License No. 37 Date 2-28-67, 19