

RECEIVED DEC 15 1975

WATER WELL REPORT

STATE OF OREGON

State Well No. 75/3w-30

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion

WATER RESOURCES DEPT SALEM, OREGON

Please type or print (Do not write above this line)

State Permit No.

(1) OWNER:

Name Major Anderson Address 3505 Salem Dallas Hwy N.W. Salem, Oregon 97304

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [X] 6" Diam. from 1 ft. to 111 ft. Gage .250

PERFORATIONS:

Perforated? [X] Yes [] No.

Type of perforator used Mills Knife Size of perforations 1/4 in. by 2 in. 126 perforations from 67 ft. to 77 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No Yield: gal./min. with ft. drawdown after hrs. Baller test 35 gal./min. with 40 ft. drawdown after 1 1/2 hrs.

(9) CONSTRUCTION:

Well seal—Material used neat cement Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 10 in.

(10) LOCATION OF WELL:

County Polk Driller's well number SW 1/4 ne 1/4 Section 30 T. 7s R. 3w W.M. Bearing and distance from section or subdivision corner 3505 Salem Dalas Hwy.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 66 ft. Static level 26 ft. below land surface. Date 5/25/75 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing Depth drilled 122 ft. Depth of completed well 122 ft. Formation: Describe color, texture, grain size and structure of materials;

Table with 4 columns: MATERIAL, From, To, SWL. Rows include soil brown, clay gray, clay blueish gray, claystone gray med hard, claystone green, claystone gray med hard, clay gray, claystone dk gray very hard, sand medium coarse.

Work started 5/20 1975 Completed 6/5 1975 Date well drilling machine moved off of well 6/6 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Paul Bello Date 6/20, 1975

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name BELLO, WELL DRILLING Address 4783 Coloma dr S.E. Salem Ore. 97302 [Signed] Paul Bello Contractor's License No. 579 Date 6/20, 1975