NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

POIK_state	Well No	651	17w-35da
POIK State	Permit No.	G-	8748

(1) OWNER:	(10) LOCATION OF WELL:			
Name Buell- Red Prarie Water Association	County Polt Driller's well number			
Address	NE 145 E 14 Section 35 T. 65 R. 7W W.M.			
	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):				
New Well Deepening Reconditioning Abandon				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 188 ft.			
Rotary Driven Domestic Industrial Municipal	Static level /6 ft. below land surface. Date 6 -/2-			
Dug Bored I Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date			
CASING INSTALLED: Threaded Welded 250 "Diam from + 2 ft. to 28 ft. Gage 250 "Diam from + 2 ft. to 320 ft. Gage 250 "Diam from ft. to ft. Gage PERFORATIONS: Perforated? Yes No.	(12) WELL LOG: Diameter of well below casing			
Type of perforator used	MATERIAL From To SWL			
Size of perforations in. by in.	Top Soil , 0 1			
perforations from ft. to ft.	Brow clay -Boulders 1 16			
perforations from ft. to ft.	Gray +6ff 16 405			
perforations from ft. to ft.				
(7) SCREENS: Well screen installed? Yes No				
Manufacturer's Name Johnson				
Type Galy Irrigator Model No.				
Diam. 6 Slot size e 100 Set from 220 ft. to 230 ft.				
Diam. 6" Slot size 100 Set from 2.90 ft. to 3.00 ft.	PFCFIVED			
(8) WELL TESTS: Drawdown is amount water level is	***OFIATR			
10 Meted below static level	JUL 3 1979			
Was a pump test made? Yes No If yes, by whom?	WATER RESOURCES DEPT			
Yield: gal./min. with ft. drawdown after hrs.	SALEM, ORECON			
all				
Seiler test 60 gal./min. with 304 ft. drawdown after 2 hrs.				
Artesian flow g.p.m.				
perature of water Depth artesian flow encountered ft.	Work started 6 1977 Completed 6 1979			
(9) CONSTRUCTION:	Date well drilling machine moved off of well			
Well seal-Material used Cement grout	Drilling Machine Operator's Certification:			
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore to bottom of sealin.				
Diameter of well bore below seal in.	[Signed] Suth Machine Operator) Date 6 1,5 , 1979			
Number of sacks of cement used in well seal sacks How was cement grout placed?	Drilling Machine Operator's License No. 1330			
bottom up				
	Water Well Contractor's Certification:			
The state of the s	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used? Yes Plugs Size: location ft.	Name AQUA-TECH Well Construction Inc.			
Did any strata contain unusable water? 🗍 Yes 🖾 No	(Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 868 Delta Dr. N. E. Salem			
Method of sealing strata off	[Signed] David Beach			
Was well gravel packed? [Yes PNo Size of gravel:	(Water Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 696 Date June 28 , 19.79			