

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

AUG 16 1973

State Well No.

75/4W-35

STATE ENGINEER  
SALEM, OREGON

State Permit No.

*Polk  
158*

(1) OWNER:

Name Frank Stricker  
Address McMinnville Ave 97128

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

12" Diam. from +1 ft. to 70 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used Mills  
Size of perforations 3/8 in. by 2 1/2 in.  
108 perforations from 50 ft. to 54 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 27 gal./min. with 11 ft. drawdown after 1 hrs.  
" " " " " "  
" " " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite & 1/4" Chaus  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 16 in.  
Diameter of well bore below seal 12 in.  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
Number of sacks of bentonite used in well seal 2 sacks  
Brand name of bentonite National  
Number of pounds of bentonite per 100 gallons  
of water 30 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Polk Driller's well number \_\_\_\_\_  
1/4 1/4 Section 35 T. 7S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 39 ft.  
Static level 34 ft. below land surface. Date 7/23/73  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing \_\_\_\_\_  
Depth drilled \_\_\_\_\_ ft. Depth of completed well \_\_\_\_\_ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Brown Clay</u>	<u>0</u>	<u>34</u>	
<u>Brown Clay + Gravel</u>	<u>34</u>	<u>39</u>	
<u>Brown sand.</u>	<u>39</u>	<u>41</u>	
<u>Clay + Gravel</u>	<u>41</u>	<u>47</u>	
<u>Gravel &amp; sand</u>	<u>47</u>	<u>54</u>	
<u>Grey shale</u>	<u>54</u>	<u>70</u>	

Work started 7/9 19 73 Completed 7/23 19 74  
Date well drilling machine moved off of well 7/25 19 74

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman A. Furell Date 7/30, 19 73  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name ROBINSON'S EOLA WELL DRILLING  
(Person, firm, or corporation) 4510 DALLAS RD., N. W. (Type or print)

Address SALEM, OREGON 97304

[Signed] George J. Robinson  
(Water Well Contractor)

Contractor's License No. 13 Date 7-31, 19 73