

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED**  
 JAN 28 1963  
 WATER WELL REPORT  
 STATE OF OREGON  
 (Please type or print)

Polk  
1672

State Well No. 7/3W-9H  
 State Permit No. Pg 2 of 2

**(1) OWNER:**

Name D. F. Blake  
 Address 2985 River Road N. W.  
Salem, Oregon

**(2) LOCATION OF WELL:**

County Polk Driller's well number  
 1/4 Section 9 T. 7 S R. 3 W W.M.  
 Bearing and distance from section or subdivision corner  
Lewis Parkhurst Donation Land Claim No. 70  
No. 70

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
 " Diam. from 2 ft. to above ground level  
10 " Diam. from 61 1/2 ft. to below ground level  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Type of perforator used Cutting torch  
 Size of perforations 3/16 in. by 8 in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
80 perforations from 41 1/2 ft. to 59 1/2 ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ ft. Was a packer used? \_\_\_\_\_  
 Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: No. 2 round  
 Gravel placed from \_\_\_\_\_ ft. to 61 1/2 ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 17 ft. below land surface Date 1-17-63  
 Artesian pressure \_\_\_\_\_ lbs per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: 70 gal./min. with 25 ft. drawdown after 3 hrs.  
 " " " " " "  
 " " " " " "  
 Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water 54 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 0  
 Depth drilled 61 1/2 ft. Depth of completed well 61 1/2 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
Sandy - Med.	4	15
Med. gravel & clay	15	40
Water bearing gravel	40	44
Med. gravel & clay	44	52
Med. gravel - water bearing	52	56
Med. gravel & clay	56	61 1/2

Work started 1-17-63 19 \_\_\_\_\_ Completed 1-25-63 19 \_\_\_\_\_  
 Date well drilling machine moved off of well 1-26-63 19 \_\_\_\_\_

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Art Clinton Well Drilling Co.  
 (Person, firm or corporation) (Type or print)

Address Rt. 1, Box 2, Independence, Oregon

Drilling Machine Operator's License No. 34

[Signed] Art Clinton  
 (Water Well Contractor)

Contractor's License No. 14 Date 1-28-63, 19 \_\_\_\_\_

**RECEIVED**  
**STATE ENGINEER STATE OF OREGON**  
**WATER WELL REPORT**  
 SALEM, OREGON

POLK  
 1672  
 Revised 7/3W-9H  
 -2-4-63 PC  
 State Well No. \_\_\_\_\_  
 State Permit No. \_\_\_\_\_ Pg 2 of 2

(1) OWNER:  
 Name Don F. Blake  
 Address 2985 River Toad N. W.  
Salem, Oregon

(2) LOCATION OF WELL:  
 County Polk Driller's well number \_\_\_\_\_  
 1/4 Section T. 7 S R. 3 W W.M. \_\_\_\_\_  
 Bearing and distance from section or subdivision corner  
Lewis Parkhurst Donation Land Claim No. 70

(3) TYPE OF WORK (check):  
 New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
 Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

(5) TYPE OF WELL:  
 Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
 \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
10" Diam. from 2' above ground level to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 \_\_\_\_\_" Diam. from 5 1/2' below ground level to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS: Perforated?  Yes  No  
 Type of perforator used Cutting torch  
 Size of perforations 3/16 in. by 8 in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
80 perforations from 3 1/2' ft. to 49 1/2' ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS: Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
 Well seal—Material used in seal \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ ft. Was a packer used? \_\_\_\_\_  
 Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: No. 2 round  
 Gravel placed from \_\_\_\_\_ ft. to 5 1/2'  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
 Static level 17 ft. below land surface Date 1-17-63  
 Artesian pressure \_\_\_\_\_ lbs per square inch Date \_\_\_\_\_

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? Stettler  
 Yield: 700 gal./min. with 25 ft. drawdown after 3 hrs.  
 " " " "  
 " " " "  
 " " " "  
 Bailor test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 54.0 Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 8  
 Depth drilled 51 1/2 ft. Depth of completed well 51 1/2 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
Sandy loam	4	15
Med. gravel & clay	15	40
Water bearing gravel	40	42
Med. gravel & Clay (brown)	42	44
Med. gravel - water bearing	44	47
Med. gravel & Clay (Brown)	47	51 1/2

Work started 1-17-63 19 \_\_\_\_\_ Completed 1-25-63 19 \_\_\_\_\_  
 Date well drilling machine moved off of well 1-26-63 19 \_\_\_\_\_

(13) PUMP:  
 Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 NAME Art Clinton Well Drilling Co.  
 (Person, firm or corporation) (Type or print)  
 Address Route 1, Box 2, Independence, Oregon  
 Drilling Machine Operator's License No. 34  
 [Signed] Art Clinton  
 (Water Well Contractor)  
 Contractor's License No. 14 Date 1-28-63, 19 \_\_\_\_\_