STATE ENGINEER Salem, Oregon						
	Catar Mar					



VV		_		
OWNER: City Water Department	MAILING		-	
•	CITY AND			
LOCATION OF WELL: Owner's No	STATE:	Salem, Or	egon	***************************************
N. E. Sw. 4 Sec. 16 T. 7 S., R. 3 W.	, W.M.			
Bearing and distance from section or subdivision				
corner S. 1600' W. 665' from NE Cor. Rober				
D.L.C. # 71		1		
		1		
Altitude at well				ł
			Χ	
TYPE OF WELL: Drilled Date Constructed		<u> </u>		-
Depth drilled 165 ft. Depth cased 118 ft		Section	16	
CASING RECORD:		_		
8 inch casing set to 118 feet				نعمين .
FINISH:				
AQUIFERS:				
WATER LEVEL:				
35 feet below surface				
PUMPING EQUIPMENT: Type American Marsh	centrigual		н	P. SCV 72 CSP 15
Capacity 400 G.P.M.				CSP 15
WELL TESTS: Drawdown65 ft. after	hours	3 90 -		
Drawdown ft. after	hours			G.P.W
USE OF WATER Intermittently	Temp	°F		, 19
	7017717171 71.21.64	1111-1111		
SOURCE OF INFORMATION Wear negrous DRILLER or DIGGER C. A. Witeraft	,			
ADDITIONAL DATA: LogX Water Level Measurements	Chemical A	nalysis	Aquifer	Test
	7			
REMARKS:		Thickness	Depth to	Bottom
Log: Clay, sand & gravel 4 no water		118	118	
Soft rock to hard - no water		42	160	
Underground stream or reservoir		5	165	