

RECEIVED

NOTICE TO WATER WELL CONTRACTOR MAY 18 1966

The original and first copy of this report are to be filed with the

STATE ENGINEER

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

SALEM OREGON STATE OF OREGON (Please type or print)

Polk 2165

35?

State Well No. 7/4w-34 State Permit No.

(1) OWNER:

Name W.H. BROWN Address RT. 1 BOX 97 INDEPENDENCE ORE

(2) LOCATION OF WELL:

County POLK Driller's well number 1/4 Section 34 T. 7S R. 4W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 40 ft. Gage 1/4"

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used MILLS Size of perforations 3/8 in. by 3 in. 100 perforations from 19 ft. to 38 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE Depth of seal 18 ft. Was a packer used? YES Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 4' 7" ft. below land surface Date 4-30-66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? STERLER SUPPLY Yield: 400 gal./min. with 15 ft. drawdown after 1 hrs. 800 " 34 " 1 " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 53 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 12" Depth drilled 40' ft. Depth of completed well 40' ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: TOP SOIL (0-3), CLAY YELLOW COLOR (3-13), CONGLOMERATE (13-25), GRAVEL COARSE (25-27), CONGLOMERATE (27-40), CLAYSTONE.

Work started 4-29-1966 Completed 4-30-1966 Date well drilling machine moved off of well 4-30-1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED + SONS (Person, firm or corporation) (Type or print) Address 3910 SILVERTON RD. SALEM ORE.

Drilling Machine Operator's License No. 187

[Signed] P.J. Sneed (Water Well Contractor)

Contractor's License No. 6 Date 4-30-1966