

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MAY 26 1966

WATER WELL REPORT

PSIX 2168

7/4w-34J

STATE ENGINEER, SALEM, OREGON 97310 STATE OF OREGON SALEM, OREGON (Please type or print)

G-3668

State Well No. State Permit No.

(1) OWNER: Name Frank Chasteen Address 194 Independence Rd. S.W. Salem, Oregon

(2) LOCATION OF WELL: County Polk Driller's well number 1/4 Section SE 34 T. 7, S R. 4, W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandonment []

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: 12" Diam. from +1 ft. to 65 ft. Gage 250

(7) PERFORATIONS: Perforated? [X] Yes [] No Type of perforator used Mills Perforator Size of perforations 1/2 in. by 3 in. 450 perforations from 42 ft. to 64 ft.

(8) SCREENS: Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Drilling Mud & Bentonite Depth of seal 30 ft. Was a packer used? No Diameter of well bore to bottom of seal 1.5 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 34 ft. below land surface Date 4-25-66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Stettler Yield: 380 gal./min. with 25 ft. drawdown after 3 hrs.

(12) WELL LOG: Diameter of well below casing 12 Depth drilled 75 ft. Depth of completed well 75 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Soil (0-2), Clay - Brown (2-35), Clay - Blue (35-64), Fine to Medium - Sand and Gravel - Brown, Clay Stone - Blue (64-75).

Work started 4-22-66 Completed 4-23-66 Date well drilling machine moved off of well 4-25-66 19

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller, Robinson, West (Person, firm or corporation) (Type or print) Address 5545 Joseph St. S.E. Salem, Oregon 59 Drilling Machine Operator's License No. [Signed] (Water Well Contractor) Contractor's License No. 37. Date 4-29-66 19