

#2 WELL

APR 27 1964

POLK  
2190

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 7/4W-36

State Permit No.

(1) OWNER:

Name DAVE KENNEDY  
Address INDEPENDENCE ORE

(2) LOCATION OF WELL:

County POLK Driller's well number  
1/4 Section 36 T. 7S R. 4W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
12" Diam. from 0 ft. to 34 ft. Gage 4"

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
Size of perforations 3/8" in. by 2 1/2" in.  
216 perforations from 22' ft. to 31' ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
Depth of seal 19' ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 16" in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 14'6" ft. below land surface Date 4-23-64  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level STETTLER  
Was a pump test made?  Yes  No If yes, by whom? SUPPLY  
Yield: 570 gal./min. with 14' ft. drawdown after 2 hrs.  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 12"  
Depth drilled 43' ft. Depth of completed well 43' ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	3
CLAY YELLOW COLOR	3	15
SAND BROWN-FINE	15	19
CONGLOMERATE	19	21
GRAVEL & SAND 2"	21	23
CONGLOMERATE	23	28
GRAVEL & SAND COARSE	28	32
CLAYSTONE - HARD.	32	43

Work started 4-20 1964 Completed 4-23 1964  
Date well drilling machine moved off of well 4-23 - 1964

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.R. SNEED & SONS  
(Person, firm or corporation) (Type or print)  
Address 3910 SILVERTON RD. SALEM, O.  
Drilling Machine Operator's License No. 187  
[Signed] J.R. Sneed  
(Water Well Contractor)  
Contractor's License No. 6 Date 4-24, 1964