	NOTICE TO WATER WELL CONTRACT <b>RECEIVED</b> NUMBER OF CONTRACT <b>RECEIVE</b> NUMBER OF	REPORT OCT 1 5 1973 State Well No. 85	14W-3	
1	STATE ENGINEER, SALEM, OREGON 97310 (Please type of		794	
(	(1) OWNER:	(10) LOCATION OF WELL:		
1	Name Rickred Water assn	County Pelk Driller's well number		
4	Address Boy 46 Providence	14 14 Section 3 T. 8 5 R/L	<u>W.M.</u>	
-	Ricknal, One	Bearing and distance from section or subdivision corner		
(	(2) TYPE OF WORK (check):		· · · · · · · · · · · · · · · · · · ·	
1	New Well Deepening CReconditioning Abandon			
2	If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(	(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	ft.	
			Data 14 - 2 17	
	Rotary Diven Domestic Industrial Municipal Cable E Jetted D	Static level 2.9 ft. below land surface		
13	Dug 🗋 Bored 🗋 Irrigation 🗆 Test Well 🗌 Other 🍎	Artesian pressure lbs. per square inch	. Date '	
	CASING INSTALLED: Threaded  Welded	(12) WELL LOG: Diameter of well below casing		
		Depth drilled ft. Depth of completed well ft.		
		Formation: Describe color, texture, grain size and structure of materials;		
		and show thickness and nature of each stratum and	aquifer penetrated,	
, ,	PERFORATIONS: Perforated?	with at least one entry for each change of formation. R position of Static Water Level and indicate principal u	eport each change in vater-bearing strata.	
	pe of perforator used Milla	MATERIAL From	n To SWL	
	Size of perforations $2/2$ in. by $24$ in.			
	Size of perforations from the to			
	<b>8 o</b> perforations from <b>5 7 5 ft</b> . to <b>6 ft</b> . <b>ft</b> .			
	perforations from			
	perforations from			
	(7) SCREENS: Well screen installed?  Yes No			
	Manufacturer's Name			
	Type Model No			
	Diam Slot size Set from ft. to ft.			
	Diam Slot size Set from ft. to ft.			
	(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
	Was a pump test made? Wes D No If yes, by whom?			
	Yield: 25 gal./min. with ft. drawdown after hrs.			
	······································			
	· · · · · · · · · · · · · · · · · · ·			
	- me haster test			
	Bailer test Mt O gal./min. with ft. drawdown after hrs.		_ <u>_</u>	
	Artesian flow g.p.m.		3 ck 2 19 7 3	
	therature of water Depth artesian flow encountered ft.	Work started O 2 19/3 Completed		
	(9) CONSTRUCTION:	Date well drilling machine moved off of well	4 3 1973	
		Drilling Machine Operator's Certification:		
	Well seal-Material used	This well was constructed under my dire	ect supervision.	
	Well sealed from land surface to ft.	Materials used and information reported above best knowledge and belief.	e are true to my	
	Diameter of well bore to bottom of seal in.	[Signed] Harry Globin Date	~ Ocl 5 19 23	
	Diameter of well bore below seal in. Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)	63	
	Number of sacks of bentonite used in well seal	Drilling Machine Operator's License No.		
	Brand name of bentonite			
	Number of pounds of bentonite per 100 gailons	Water Well Contractor's Certification:	• • • • • •	
	of water lbs./100 gals.	This well was drilled under my jurisdiction true to the best of my knowledge and belief.	and this report is	
	Was a drive shoe used?  Yes No Plugs		Dorllin	
	Did any strata contain unusable water? 🗌 Yes 🗌 No	Name (Person, firm or corporation)	(Type or print)	
	Type of water? depth of strata	Address 4570 Dalles - S.	dem Huy	
	Method of sealing strata off	Obs. V Que		
	Was well gravel packed?  Yes No Size of gravel:	(Water Well Contractor)		
	Gravel placed from ft. to ft.	Contractor's License No Date	<u>2 - 12 , 1973</u>	

l

----

(USE ADDITIONAL SHEETS IF NECESSARY)

---

SP+45656-119

. . . . . . . . . . . . .