

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

WATER WELL REPORT

RECEIVED

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER

Polk 29778

State Well No. 8/4w-28P

State Permit No. _____

G-4332

(1) OWNER:

SALEM OREGON

Name City of Monmouth c/o Ken Martin, Mgr.
Address Monmouth, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded 1 1/2"

" Diam. from _____ ft. to _____ ft. Gage _____
12" Diam. from 1 ft. above land surface to _____
" Diam. from 66 ft. below land surface to _____

PERFORATIONS:

Perforated? Yes No

Type of perforator used Cutting torch 2.2 in/st
Size of perforations 5/16 in. by 9 in.
_____ perforations from _____ ft. to _____ ft.
80 perforations from 47 ft. to 66 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 37 1/2 ft. below land surface Date 3/29/68
Man pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler
Yield: 270 gal./min. with 26 1/2 ft. drawdown after 3 hrs.
200 " 12 1/2 " 1 Hr. 40 min.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 50° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Heavy clay & bentonite
Depth of seal _____ 18 ft.
Diameter of well bore to bottom of seal _____ 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel #2 round
Gravel placed from _____ 18 ft. to _____ 66 ft.

(11) LOCATION OF WELL: City Well # 1

County Polk Driller's well number _____
1/4 Section 28 T. 8 S. R. 4 W. W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 72 ft. Depth of completed well 72 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	2'	
Gray clay	2'	3 1/2'	
Coarse sand & Med. Gravel (water bearing)	3 1/2'	66'	37 1/2'
Blue clay	66'	72'	

Work started 2/28/68 19 _____ Completed 3/7/68 19 _____

Date well drilling machine moved off of well 3/12/68 19 _____

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Art Clinton Date April 6, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 34

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ART CLINTON WELL DRILLING CO.
(Person, firm or corporation) (Type or print)

Address Rt.1, Box 2, Independence, Oregon 97351

[Signed] Art Clinton
(Water Well Contractor)

Contractor's License No. 14 Date April 6, 1968, 19 _____