

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

JUN 28 1966

State Well No. _____
CON
State Permit No. _____

Well #6

Well no. 5-
P.B.K.
3739

9/4w-3C

G-3857

(1) OWNER:

Name Frank Kranger
Address Rt. 1 Box 18 2nd St.

(2) LOCATION OF WELL:

County Polk Driller's well number _____
1/4 Section 3 T. 9S R. 4W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0 ft. to 25 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Arch
Size of perforations 3/4 in. by 16 in. Raised
perforations from 15 ft. to 25 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Gravel
Depth of seal top of bore as a packer used? no
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: course
Gravel placed from 0 ft. to 25 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 11 ft. below land surface Date 6/2
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? owner
Yield: 200 gal./min. with 6 ft. drawdown after 4 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 25 ft. Depth of completed well 25 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Top soil clay</u>	<u>0</u>	<u>15</u>
<u>Coarse Gravel</u>	<u>15</u>	<u>25</u>
<u>Slotted back 2 1/2" x 3'</u>		
<u>Sand & gravel</u>		
<u>10" bitum perforations</u>		

Work started 5/5/66 Completed 6/2/66
Date well drilling machine moved off of well 6/3/66

(13) PUMP:

Manufacturer's Name _____
Type: Electric H.P. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R. C. WESTON
Address Rt. 2 Box 25 IADALLAS
Drilling Machine Operator's License No. 27
[Signed] R. C. Weston
Contractor's License No. 244 Date 6/3, 1966