NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED DEC 1 1978 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

NC Polk

State Well No. 9S/4W-10

State Permit No. 3802

(1) OWNER:
Name Tuckiamuta Domestic Water Ass
c/o
Address Boatwright Engineers 3613 - 12th St. SE Salem Ore 97302

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☑
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
12" Diam. from +1 ft. to 41 ft. Gage 1250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used
Size of perforations 3/8 in. by 2½ in.
322 perforations from 25 ft. to 35 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom?
Yield: 350 gal./min. with 2 ft. drawdown after 24 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement.
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 25 sacks
How was cement grout placed? Pumped.

Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Polk. Driller's well number
¼ ¼ Section 10 T. 9S R. 4W. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 21 ft.
Static level 14 ft. below land surface. Date 10-23-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 41½ ft. Depth of completed well 41½ ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	18½	
Clay, Sand, Fine Gravel	18½	21	
Small to Med Gravel + Sand	21	35	
Blue Clay	35	41½	

Work started 10-20 19 78 Completed 10-23 19 78
Date well drilling machine moved off of well 10-23 19 78

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Norman A Farrell Date 10-31, 1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name EOLA WELL DRILLING 4510 DALLAS RD. N.W. SALEM, OR 97304
(Person, firm or corporation) (Type or print)
Address
[Signed] Lamit H Brandt
(Water Well Contractor)
Contractor's License No. 619 Date , 19

EOLA WELL DRILLING 4510 DALLAS RD N W SALEM OR 97304

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119