

WATER WELL REPORT
STATE OF OREGON

RECEIVED

MAR 6 1985

WATER RESOURCES DEPT
PLEASE TYPE IN INK
SALEM, OREGON

Polk 3884

State Well No. 95/4W-15ab

State Permit No.

(1) OWNER:

Name Paul Murphy
Address 9295 Hiltman Rd.
City Independence State OR

(2) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air, Driven, Dug, Bored, Rotary Mud, Irrigation, Thermal, Industrial, Test Well, Withdrawal, Municipal, Other, Reinjection

(4) PROPOSED USE (check):

Steel Threaded, Plastic Welded, Gauge 2.50

(5) CASING INSTALLED:

6" Diam. from 11/2 ft. to 42 ft. Gauge 2.50

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes X No
Type of perforator used Touch
Size of perforations 34/11 in. by 5 in.
perforations from 32 ft. to 40 ft.

(7) SCREENS:

Well screen installed? Yes X No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No X
gal./min. with ft. drawdown after hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test 50 gal./min. with 8 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes X No
Well seal-Material used CEMENT
Well sealed from land surface to 27 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 4 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? Method C
Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes X No Plugs Size: location ft.
Did any strata contain unusable water? Yes X No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes X No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Polk Driller's well number
NW 1/4 NE 1/4 Section 15 T. 9 S R. 4W W.M.
Tax Lot # Lot Blk Subdivision

Address at well location:

9875 BUENA VISTA HWY.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 27 ft.
Static level 16 ft. below land surface. Date 2/23/85
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 42 ft. Depth of completed well 42 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Content: BROWN SANDY SOIL (0-27), BROWN SAND & GRAVEL (27-42)

Work started 2/22/85 19 Completed 2/23/85 19
Date well drilling machine moved off of well 2/23/85 19

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:
Bond 615 Issued by:
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name RIDGERS WELL DRILLING (Type or print)
Address Rt. 1 Box 256 Albany (Type or print)
[Signed] Pat Ridger Water Well Constructor
Date 2/23/85 19

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310
within 30 days from the date of well completion. SP\*45292-690