

Amended 3/27/2024

(WELL I.D.)# L 127718

(START CARD) # 218174

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number Jon Lauer, Address Bethel Heights Rd NW, City Salem, State ORE, Zip 97304

(2) TYPE OF WORK: Alteration (repair/recondition)

(3) DRILL METHOD: Excavator

(4) PROPOSED USE: Domestic

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes, Depth of Completed Well 216 ft.

HOLE SEAL: Diameter 10", From 2' to 6', Material Bentonite, Sacks or pounds 1 Bag .545

How was seal placed: Method Filled from the top with dry Bentonite. Backfill placed from 0 ft. to 0 ft. Gravel placed from 0 ft. to 0 ft.

(6) CASING/LINER: Table with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded for Casing and Liner.

(7) PERFORATIONS/SCREENS: Perforations Method, Screens Type, Material

Table for perforations/screens with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Pump, Bailer, Air, Artesian. Yield gal/min, Drawdown, Drill stem at, Time.

Temperature of water, Depth Artesian Flow Found, Was a water analysis done?, Did any strata contain water not suitable for intended use?

(9) LOCATION OF WELL by legal description: County Polk, Latitude 45.0455, Longitude -123.1559, Township 6 N, Range 4 W, Section 15 SE, 1/4 SE, 1/4, Tax Lot 600, Block, Subdivision, Street Address of Well (or nearest address) Same

(10) STATIC WATER LEVEL: NR ft. below land surface, Date, Artesian pressure lb. per square inch, Date

(11) WATER BEARING ZONES: Depth at which water was first found

Table for Water Bearing Zones with columns: From, To, Estimated Flow Rate, SWL

(12) WELL LOG: Ground Elevation

Table for Well Log with columns: Material, From, To, SWL. Includes text: Well Bore and Casing was not Disturbed. Installed seal from 2' below ground to bottom of Well pit @ 6'. 10" Sawn tube was installed around 6" casing and filled to the top with Bentonite. 3/4-Rock was backfilled to 2.5' then Cement from Pitless adapter to Rock. Cement was contoured to a 2" Drain line. Drain line ran Down-gradient to daylight. Back flow device was installed. Manhole cap installed with gasket seal. Manhole cap has Water Well Marked on top. Previous log POLK 54117. RECEIVED 9/19/2023 OWRD

Date started 08/11/2023 Completed 08/28/2023

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. WWC Number, Signed, Date

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief. Robinson Well Drilling WWC Number 1585, Signed Ron Spangler, Date 10/26/2023