

STATE OF OREGON WATER SUPPLY WELL REPORT

POLK 54916

WELL I.D. LABEL# L 152217 START CARD # 1073546 ORIGINAL LOG #

5/8/2024

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. 02 First Name PAUL Last Name SCHERBAK Company TPWC, INC / LINGUA FRANC WINERY Address 235 N BLOOMFIELD RD City CANANDAIGUA State NY Zip 14424

(2) TYPE OF WORK [X] New Well [ ] Deepening [ ] Conversion [ ] Alteration (complete 2a & 10) [ ] Abandonment (complete 5a)

(2a) PRE-ALTERATION Dia + From To Gauge Stl Plstc Wld Thrd Casing: Seal:

(3) DRILL METHOD [X] Rotary Air [ ] Rotary Mud [ ] Cable [ ] Auger [ ] Cable Mud [ ] Reverse Rotary [ ] Other

(4) PROPOSED USE [ ] Domestic [ ] Irrigation [ ] Community [X] Industrial/ Commercial [ ] Livestock [ ] Dewatering [ ] Thermal [ ] Injection [ ] Other

(5) BORE HOLE CONSTRUCTION Special Standard [ ] (Attach copy) Depth of Completed Well 183.00 ft.

Table with columns: Dia, From, To, Material, From, To, Amt, sacks/lbs. Rows include Bentonite and Cement with 5% Bento.

Seal placement method [ ] A [ ] B [X] C [ ] D [ ] E [X] Other: POURED BENTONITE Backfill placed from 123 ft. to 127 ft. Material DRILL CUTTINGS

(5a) ABANDONMENT USING UNHYDRATED BENTONITE Proposed Amount Actual Amount

(6) CASING/LINER Casing Liner Dia + From To Gauge Stl Plstc Wld Thrd Shoe [ ] Inside [ ] Outside [ ] Other Location of shoe(s) Temp casing [X] Yes Dia 12 From + 2 To 4

(7) PERFORATIONS/SCREENS Perforations Method Saw Screens Type Material Perf/ Casing/ Screen Dia From To Scrn/slot width length # of slots Tele/ pipe size

(8) WELL TESTS: Minimum testing time is 1 hour [ ] Pump [ ] Bailer [X] Air [ ] Flowing Artesian Yield gal/min Drawdown Drill stem/Pump depth Duration (hr)

Temperature 61 °F Lab analysis [X] Yes By SDI, Iron Not Detected Water quality concerns? [ ] Yes (describe below) TDS amount 103 ppm

(9) LOCATION OF WELL (legal description) County POLK Twp 6.00 S N/S Range 3.00 W E/W WM Sec 6 SE 1/4 of the SE 1/4 Tax Lot 100

(10) STATIC WATER LEVEL Date SWL(psi) + SWL(ft) Existing Well / Pre-Alteration Completed Well 5/8/2024 2

Table with columns: SWL Date, From, To, Est Flow, SWL(psi), + SWL(ft). Rows for 5/2/2024 and 5/3/2024.

(11) WELL LOG Ground Elevation From To Material Topsoil, brown Clay, tan Clay, mix colors Clay, gray Clay, dark brown stiff Clay, gray & blue w/sand seams Basalt, gray & brown weathered Basalt, red & brown medium Basalt, brown & gray broken medium Basalt, gray & brown harder Basalt, multicolored broken medium Basalt, brown & yellow medium Basalt, tan & brown broken medium Basalt, gray & brown fractured hard Basalt, brown broken hard Basalt, brown & black fractured hard Basalt, gray & brown broken

Construction Begin Date 5/2/2024 Begin Time 08 30 End Date 5/8/2024

(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. License Number 1884 Date 5/8/2024 Signed JUSTIN MELONUK (E-filed)

(bonded) Water Well Constructor Certification I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. License Number 2006 Date 5/8/2024 Signed CHRISTEN BLAND (E-filed) Contact Info (optional) Skyles Well Drilling 503-656-2683



WATER SUPPLY WELL REPORT - Map with location identified must be attached and shall include an approximate scale and north arrow

POLK 54916

5/8/2024

Map of Hole

<b>STATE OF OREGON WELL LOCATION MAP</b>	<b>Oregon Water Resources Department</b> 725 Summer St NE, Salem OR 97301 (503)986-0900	
This map is supplemental to the WATER SUPPLY WELL REPORT		
<b>LOCATION OF WELL</b>	<b>Well Label: 152217</b>	
Latitude: 45.07392500 Datum: WGS84	<b>Printed: May 8, 2024</b>	
Longitude: -123.09343880	<small>DISCLAIMER: This map is intended to represent the approximate location the well. It is not intended to be construed as survey accurate in any manner.</small>	
Township/Range/Section/Quarter-Quarter Section:	<small>Provided by well constructor</small>	
WM6.00S3.00W6SESE		
Address of Well:		
9675 HOPEWELL RD NW, SALEM, OREGON 97304		

