

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON

within 30 days from the date of well completion.

RECEIVED SEP 27 1972 STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON (Please type or print)

(Do not write above this line)

OWNER 325

State Well No. 3N/17E-23

State Permit No. 6-5851

3N/17E-23 bdb

(1) OWNER: CORPS OF ENGINEERS

Name LE PAGE PARK SITE A
Address BLDG 602 CITY COUNTY AIRPORT WALLA WALLA, WASH.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) CASING INSTALLED:

12" Diam. from 0 ft. to 40 ft. Gage 375
8" Diam. from 0 ft. to 143 ft. Gage 322

(6) PERFORATIONS:

Perforated? [] Yes [X] No.
Type of perforator used
Size of perforations in. by in.

(7) SCREENS:

Well screen installed? [X] Yes [] No
Manufacturer's Name U.O.P. JOHNSON
Type STAINLESS STEEL Model No.
Diam. 8 Slot size 100 Set from 143 ft. to 158 ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom?
Yield: 300 gal./min. with 5 ft. drawdown after 72 hrs.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 20 sacks
Number of sacks of bentonite used in well seal
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water
Was a drive shoe used? [X] Yes [] No Plugs Size: location
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County SHERMAN Driller's well number 5419
NW 1/4 SE 1/4 Section 23 T. 3N R. 17E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 141 ft.
Static level 12 ft. below land surface. Date 9/5/72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 158 ft. Depth of completed well 158 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include FILL, GRAVEL, SAND, SOME GRAVEL, TALUS, SOME GRAVEL, WATER BEARING GRAVEL.

Work started AUG 14 1972 Completed SEPT 12 1972
Date well drilling machine moved off of well SEPT 13 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 9/25 19/72
(Drilling Machine Operator)
Drilling Machine Operator's License No. 57

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R.J. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORTLAND ORE
[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date SEPT 25, 1972