

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310

JAN 10 1979

STATE OF OREGON

(Please type or print)

WATER RESOURCES DEPT.
SALEM, OREGON

TILL
1007

State Well No. 65/10w-4
State Permit No. _____

(1) OWNER:

Name Louise Thompson
Address 10055 State Creek Rd. Marshfield Ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(10) LOCATION OF WELL:

County Tillamook Driller's well number _____
1/4 1/4 Section H T. 6S R. 10W W.M. _____
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 60 ft.
Static level 4" ft. below land surface. Date 11/10/78
Artesian pressure _____ lbs. per square inch. Date _____

CASING INSTALLED:

Threaded Welded
6" Diam. from +1 ft. to 25 ft. Gage 250
_____ " Diam. from _____ ft. to _____ ft. Gage _____
_____ " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
_____ " " " " " " " " " " "
" Stem at 90. " " " " " " " " " " "
" Stem at 90. " " " " " " " " " " "
Better test 18 gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? pumped

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 93 ft. Depth of completed well 93 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>top soil</u>	<u>0</u>	<u>4</u>	
<u>Clay tan</u>	<u>4</u>	<u>8</u>	
<u>Cracked Rock</u>	<u>8</u>	<u>22</u>	
<u>Basalt Rock Hard.</u>	<u>22</u>	<u>93</u>	

RECEIVED
DEC 4 1978
WATER SOURCES
SALEM, OREGON

Work started Nov 8 19 78 Completed Nov 10 19 78
Date well drilling machine moved off of well Nov 10 19 78

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Norman O. Ferrell Date Nov 18, 1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 846

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name EOLA WELL DRILLING
(Name of contractor or corporation) (Type or print)
Address SALEM, OR
[Signed] Lanet H. Berndt
(Water Well Contractor)
Contractor's License No. 619 Date 11-22, 19 78