NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT TILL

STATE OF OREGON

(Please type or print)
(Do not write above this line)



State Well No. ZN/10W-ZOad

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:		
Name CITY OF ROCKAWAY	County TILLAMED & Driller's well number 5561		
Address P.O. Box 35 ROCKAWAY ORK	5E 1/4 NE1/4 Section 20 T. 2N R. 10W W.M.		
(a) mypy on work (1 1)	Bearing and distance from section or subdivision corner		
(2) TYPE OF WORK (check): No Z			
New Well Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 2 ft.		
Rotary Driven Domestic Industrial Municipal	Static level 2 ft. below land surface. Date //17/80		
Cable Jetted	Artesian pressure lbs. per square inch. Date		
(5) CASING INSTALLED: Threaded Welded Welded 22 " Diam. from	Depart drifted SO It. Deptit of completed wen SO It.		
(6) PERFORATIONS: Perforated? Yes No.	and show thickness and nature of each stratu with at least one entry for each change of forma position of Static Water Level and indicate prin	ım and aquifer pe ition. Report each (netrated,
Type of perforator used	MATERIAL	From To	SWL
Size of perforations in by in	SAND	0 35	
perforations from ft. to ft.	SAND AND GRAVEL	35 50	
perforations from ft. to ft.			
perforations from ft. to ft.			
(7) SCREENS: Well screen installed? Wyes D No.			
(7) SCREENS: Well screen installed? Yes I No Manufacturer's Name DOP JOHNSON	-	 	
Type STAINLESS STEEL Model No.			
Diam. Slot size Description 30 ft. to 50 ft.			
Diam Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	BECEIVED		
was a pump test made? Yes No If yes, by whom? STRASSE	₹ FFR 2 3 1980		
add: 250 gal./min. with 6.5ft. drawdown after /2 hrs.	TER DECOURCES DEPT		
II	WATER RESOURCES DEPT		
II	SALEM, OREGON	<u> </u>	
Bailer test gal./min. with ft. drawdown after hrs.			
esian flow g.p.m.			
Temperature of water Depth artesian flow encountered ft.	Work started JAN 4 1980 Complete	ed 19N 21	1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well	JAN 21	19 80
Well seal—Material used CEMENT GROUT	Drilling Machine Operator's Certification:		
Well sealed from land surface to 20 ft.	This well was constructed under my	direct supers	vision.
Diameter of well bore to bottom of sealin.	Materials used and information reported best knowledge and belief.	above are true	to my
Diameter of well bore below sealin.		Data 754 25	1080
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)		
How was cement grout placed? GROUT PUMPEO	Drilling Machine Operator's License No941		
CASILLE WAS PENOUSED	Water Well Contractor's Certification:		
CASING WAS REMOVED	This well was drilled under my jurisdi	ction and this w	nort is
Was a drive shoe used? Yes □ No Plugs Size: location ft.	true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes No	Name K. STRASSER DEILUPG Co (Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address 8110SESUNSET LANE		") Dez
Method of sealing strata off	60 1. 1. 1. 1.	12	j
Was well gravel packed? X Yes I No Size of gravel: SALID	[Signed] (Water Well Contra	artor)	
Gravel placed from ft. to ft.	Contractor's License No Date 7	EB ,25	108
A lea	, Date .f	/	. ١٧.٣.٠٠