

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MAR 26 1969

RECEIVED WATER WELL REPORT

TILL 212

STATE OF OREGON

State Well No. 1N/8W-25oc

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

(Please type or print) (Do not write above this line)

State Permit No.

(1) OWNER:

Name Oregon State Forest Serv. Address Forest Grove - Keening Cr.

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [x]

(11) LOCATION OF WELL:

County Tillamook Driller's well number 121 SW 1/4 NE 1/4 Section 25 T. 1N R. 8W W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 114 ft. Depth of completed well 114 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include TOP SOIL, Brown Clay, Brown Sand, Large gravel, Basalt, Marine Rock.

CASING INSTALLED:

6" Diam. from 0 ft. to 43 ft. Gage 280

PERFORATIONS:

Perforated? [] Yes [x] No. Type of perforator used. Size of perforations in. by in.

(7) SCREENS:

Well screen installed? [] Yes [x] No. Manufacturer's Name, Type, Model No., Diam., Slot size, Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 33 ft. below land surface Date 3-10-69. Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [] Yes [x] No. Yield: gal./min. with ft. drawdown after hrs.

(10) CONSTRUCTION:

Well seal—Material used cement droat. Depth of seal 33 ft. Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [] Yes [x] No. Was a drive shoe used? [x] Yes [] No. Did any strata contain unusable water? [] Yes [x] No. Type of water? depth of strata. Method of sealing strata off. Was well gravel packed? [] Yes [x] No. Size of gravel: Gravel placed from ft. to ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jim Shelburne Date 3-21-69 (Drilling Machine Operator)

Drilling Machine Operator's License No. 397

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Blue Water Drilling Co. (Person, firm or corporation) (Type or print)

Address RT 1 Box 75 Dayton, Ore.

[Signed] Robert Shelburne (Water Well Contractor)

Contractor's License No. 417 Date 3-21-69