NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

RECEIVED

State Well No.

JUN 25 1976

State Permit No. (Do not write above this line) WATER RESOURCES DEPT.

(1) OWNER:	(10) LOCATION OF WELL:
Name Twin Rocks Conference Grounds	County Tillimook Driller's well number
Address Rt 1 Box 325	14 14 Section 7 T. IN R. 10W W.M.
Rockaway, OR 97136	Bearing and distance from section or subdivision corner A A D
(2) TYPE OF WORK (check):	Scaring and distance from Section of Sabarysion Confer
New Well ∰ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) YEARDED TREVERY CO
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.  Depth at which water was first found 85 ft.
Rotary Driven D	
Cable ☑ Jetted ☐ Domestic ☑ Industrial ☐ Municipal ☐ Dug ☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Static level 85 ft. below land surface. Date 16 Jun 7
Dug   Bored   Irrigation   Test Well   Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded	(19) WELL LOC.
5/80D." Diam. from 0 ft. to 116-5 ft. Gage .250	(12) WELL LOG: Diameter of well below casing6!!
	Depth drilled 120 ft. Depth of completed well 120 ft.
	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
	with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Cutting torch	MATERIAL From To SWL
Size of perforations 1/4 in. by 12 in.	clay 0 )
40 perforations from 70 ft. to 116 ft.	soft brown rock 4 18
perforations from ft. to ft.	medium hard brown sandstone 18 62
perforations from ft. to ft.	hard rock 62 103
(E) CODESTATO	Bard rock broken layers 103 110
(7) SCREENS: Well screen installed? ☐ Yes ঽ No	basalt broken layers 110 120 85 f
Manufacturer's Name	most water came from 103
Type Model No	to 120
Diam. Slot size Set from ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? X Yes   No If yes, by whom? Meeker	
wield: 30 gal./min. with 8 ft. drawdown after 1 hrs.	
" " "	
n n n	
Bailer test gal./min. with ft. drawdown after hrs.	
ertesian flow g.p.m.	
mperature of water Depth artesian flow encountered	
<del>*</del>	Work started May 26 1976 Completed Jun 16 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well Jun 18 1976
Well seal-Material usedcement grout	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision.  Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below seal in.	[Signed] John M / Cell Bate Jun 23, 19 76
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal 0sacks	Drilling Machine Operator's License No50
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? X Yes No Plugs Size: location ft.	Name JOHN MEEKER WELL DRILLING
Did any strata contain unusable water?   Yes   No	(Porson, firm or corporation) (Type or print)
Type of water? depth of strata	Address 2902 Portland Rd Newberg, Or 97132
Method of sealing strata off	[Signed] John H. Leeker
Was well gravel packed?   Yes □ No Size of gravel: 3/8-3/4	(Water Well Contractor)
Gravel placed from70ft. toft.	Contractor's License No. 111 Date June 23, 1976.
	1