NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

ILL 227 Insufficient yield Abandoned 8/25/78

State Well No. 1N-10W-7

State Permit No.

RECEIVED NOV - 6 1975 WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER:
Name Twin Rocks Friends Conference Association
Address Rt 1 Box 325
Rockaway, OR 97136

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6 5/8 OD" Diam. from 0 ft. to 48 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☒ Yes ☐ No
Manufacturer's Name Johnson Screen
Type 10 slot stainless steel Model No.
Diam. 5 5/8 Slot size 10 Set from 48 ft. to 58 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Meeker
Yield: 25 gal./min. with 7 ft. drawdown after 3 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Tillamook Driller's well number
¼ ¼ Section 7 T. 1N R. 10W W.M.
Bearing and distance from section or subdivision corner A AD

(11) WATER LEVEL: Completed well.
Depth at which water was first found 40 ft.
Static level 27 ft. below land surface. Date 11-3-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 68 ft. Depth of completed well 60 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	5	
brown sand & clay some small gravel	5	18	
brown clay	18	38	
fine beach sand blue gray	38	52	
fine beach sand light brown	52	68	27 ft

Work started Oct 28 1975 Completed Nov 3 1975
Date well drilling machine moved off of well Nov 5 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John H Meeker (Drilling Machine Operator) Date Nov 5, 1975
Drilling Machine Operator's License No. 50

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name JOHN MEEKER WELL DRILLING (Person, firm or corporation) (Type or print)
Address 2902 Hoover Blvd, Newberg, Or 97132
[Signed] John H Meeker (Water Well Contractor)
Contractor's License No. 111 Date Nov 5, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119