NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,

## WATER WELL REPORT

## STATE OF OREGON

TILL	<b>,</b>
270 /	State Well No. ZN/10W-ZUad
	State Permit No

SALEM, OREGON 97310 (Please type within 30 days from the date of well completion. (Do not write about the completion)	State Permit N	<b>9.</b>
(1) OWNER:	(10) LOCATION OF WELL:	
	County TILLAMOOK Driller's well no	mher 5562
Name CITY OF ROCKAWAY Address PO, BOX 35 ROCKAWAY, ORE	SE 14 NE 14 Section 20 T. 2N	
Authors 1,0 EUX 30 AUCK 40011,0 Files		
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	on corner
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐		· .
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	~T1
(3) TYPE OF WELL: (4) PROPOSED USE (check):	_	en.
	Depth at which water was first found	6 It.
Jetted [] Domestic [] Industrial [] Municipal [8]		urface. Date 1/31/80
Bored   Irrigation   Test Well   Other	Artesian pressure lbs. per squar	e inch. Date
(5) CASING INSTALLED: Threaded Welded W	(12) WELL LOG: Diameter of well h	.,
12 Diam. from +1 ft. to 29 ft. Gage 1330	Depth drilled 50 ft. Depth of comple	elow casingtt.
8" Diam. from + 1 ft. to 30. ft. Gage 330.		
ft. Gage ft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratus	n and aquifer penetrated,
(6) PERFORATIONS: Perforated?   Yes \nldot No.	with at least one entry for each change of formal position of Static Water Level and indicate prin	
Type of perforator used	MATERIAL	From To SWL
Size of perforations in. by in.	SAND AND GRAVEL	0 35
perforations from ft. to ft.	SAND AND GRAVEL	35 50
perforations fromft. toft.	<u> </u>	
perforations from ft. to ft.		
(7) SCREENS: Well screen installed? Yes \( \text{No P OHUSOU} \)		
Type STITINUESS STEEL Model No.		
Diam Slot size Set from ft. to ft.	277 TT 277 E33 8 3 3 4 500 Htts	
Diam. Slot size Set from ft. to ft.	FIFTIVEU	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	1 LE & J 1080	
as a pump test made? Yes 🗆 No If yes, by whom?	WATEL FISOURCES DEPT	
meld: 250 gal./min. with 21, 7 ft. drawdown after 12 hrs.		•
n n n		
" " "		
Bailer test gal./min. with ft. drawdown after hrs.		
tesian flow g.p.m.		
Temperature of water Depth artesian flow encountered ft.	Work started JAN 21 19 80 Complete	d FEB 5 1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well	FEB 6 1980
Well seal—Material used CEMENT GROUT	Drilling Machine Operator's Certification:	······································
Well sealed from land surface toft.	This well was constructed under my	direct supervision.
Diameter of well bore to bottom of seal in.	Materials used and information reported best knowledge and belief.	above are true to my
Diameter of well bore below seal		Date FE8251980
Number of sacks of cement used in well sealsacks	Drilling Machine (Spyrator)	
How was cement grout placed? GROUT WAS TUMPED	Drilling Machine Operator's License No.	741
THRU I IN PIPE AS 16 IN	Water Wall Centractor's Contilication	
CASING WAS REMOVED	Water Well Contractor's Certification:	ation and this never is
	This well was drilled under my jurisdi true to the best of my knowledge and bel	
Was a drive shoe used? Yes \( \subseteq \) No Plugs Size: location ft.	Name RJ. STRASSER DRILL	
Did any strata contain unusable water?   Yes No	(Person, firm or corporation)  Address \$110 SE SUNSETA	(Topsor print)
Type of water? depth of strata	Address 8110 SE 3003E1A	WE VORTUND CRE
Method of sealing strata off	[Signed] (Coben & I ha	SSOT
Was well gravel packed? Yes No Size of gravel:	(Water Well Contr	4EB 25 1980
Gravel placed fromft. toft.	Contractor's License No. 20 Date	140 - 1900