NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

TILL 435

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED DEC 16 1976 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 1S/8W-18
State Permit No.

(1) OWNER:
Name David Williams
Address 15015 Wilson River Hy, Tillamook

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 1 above to 18 ft. Gage .250
" Diam. from ft. to ft. Gage
5" Diam. from 15 ft. to 260 ft. Gage PVC 125#

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used skil saw
Size of perforations 1/8 in. by 6 in. in P.V.C.
144 perforations from 20 ft. to 260 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 1½ gal./min. with 250 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite Black Hills
Number of pounds of bentonite per 100 gallons of water 30 lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Tillamook Driller's well number
¼ ¼ Section 18 T. 1S R. 8W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 15 ft. below land surface. Date 12-9-76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 260 ft. Depth of completed well 260 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	4	
Boulders	4	19	
Blue sandstone	19	60	
Blue claystone	60	65	
Blue sandstone	65	105	
Blue claystone layers with sandstone	105	114	
Blue sandstone	114	260	

Work started 11-30 19 76 Completed 12-9 19 76
Date well drilling machine moved off of well 12-9 19 76

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Paul E. Dickerson (Drilling Machine Operator) Date 12-9, 1976
Drilling Machine Operator's License No. 549

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Robinson Fala Drilling (Person, firm or corporation) (Type or print)
Address 4510 Dallas-Salem Hwy
[Signed] George H. Robinson (Water Well Contractor)
Contractor's License No. 13 Date 12-13, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119