STATE ENGINEER Salem, Oregon



Well Record

STATE WELL NO. 1/9W-27E (1)
COUNTY Tillamook
APPLICATION NO GR-250

		APPLICATION NO. GH-250
OWNER: Virgil Chadwick	MAILING ADDRESS:	
LOCATION OF WELL: Owner's No.	CITITIST A BITE	
SW 1/4 NW 1/4 Sec. 27 T. 1 S, R. 9 W		
Bearing and distance from section or subdivision	, ** .1*1.	
corner 275' E. & 1020' N. of W. 1/4 Cor. Sec.	27. 4	ECI
Altitude at well 15 to 18 feet	KP KP Shuyen da	2 22
TYPE OF WELL: Drilled Date Constructed 11-	58	
Depth drilled 197 Depth cased 197	**********	Section27
CASING RECORD:		
8 inch		
FINISH:		
AQUIFERS:		
Agoirens.		
WATER LEVEL:		
80		
PUMPING EQUIPMENT: TypeTurbine Capacity500 G.P.M.	*************************	H.P. 15
WELL TESTS:		
Drawdown ft. after	hours	G.P.M
Drawdown ft. after	hours	G.P.M
USE OF WATER Irrigation	Temp. °F	F 10
SOURCE OF INFORMATION		
ADDITIONAL DATA:		
Log X Water Level Measurements	Chemical Anal	ysis Aquifer Test
REMARKS:		

STATE ENGINEER Salem, Oregon

State	Well	No.	1/9W-27E(1)			
County Tillamook						
	-		GR-250			

Well Log

Owner: Virgil Chadwick	Owner's No				
Driller:	Date Drilled				
CHARACTER OF MATERIAL	(Feet Delon	/ land surface)	Thickness (feet)		
Soil	i	5	5		
Clay	[20	15		
_Cemented Gravel	20	45	25		
Water Gravel	45	50	5		
Cemented Gravel	50	60	10		
Water Gravel	60	65	55		
Cemented Gravel	65	115	50		
Water Gravel	115	120	5		
Cemented Gravel	120	154	34		
Water Gravel	154	160	6		
Cemented Gravel	160	190	30		
Water Gravel	190	195	5		
Shale	195	197	2		
等" "					