

798

OBSERVATION WELL

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

State Well No. 1/9W-29

State Permit No. G-1115

Our No. 2 Well

TILLAMOOK

(1) OWNER:

Name Fairview Water District, Inc., Address 403 Maralf Drive, Tillamook, Oregon

(2) LOCATION OF WELL:

County Tillamook Owner's number, if any - No. 2 N W 1/4 of S 1/4, Section 29 T. 1 S R. 9 W W.M. Bearing and distance from section or subdivision corner North 733.2' - East 224.5' from S.W. Corner Tripp D.L.C. No. 142

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [X] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [X]

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 150 ft. Gage 1/2" steel

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used SIZE of perforations 1/2 in. by 1 in. perforations from 132 ft. to 150 ft.

(8) SCREENS:

Well screen installed [X] Yes [ ] No Manufacturer's Name Pump, Pipe & Power Co., Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well concrete packed? [X] Yes [ ] No Size of gravel: Concrete & Clay Gravel placed from 0 ft. to 10 ft. Was a surface seal provided? [X] Yes [ ] No To what depth? 10 ft. Material used in seal - Concrete Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 34 ft. below land surface Date 10-27-53 Artesian pressure None lbs. per square inch Date

Log Accepted by:

[Signed] /? Date ? 19

Fairview Water District

11-53

(USE ADDITIONAL SHEETS IF NECESSARY)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? Health Dept. Yield: 600 gal./min. with 78 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well 12 inches. Depth drilled 150 ft. Depth of completed well 140 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Top soil, Cemented gravel, Clay, Gravel perforated, etc.

Work started 11 19 53 Completed 11 19 53

(13) PUMP:

Manufacturer's Name Pump, Pipe & Power Co., Type: Electric Centrifugal H.P. 50

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harty Brothers, address unknown (Person, firm, or corporation) (Type or print)

Address

Driller's well number

[Signed] Harty Brothers (Well Driller)

License No. Date 11 19 53