

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED

WATER WELL REPORT

WATER RESOURCES DEPARTMENT, STATE OF OREGON
SALEM, OREGON 97310

SEP 08 1980

STATE OF OREGON

TILL
535

State Well No. 15/9w-3300

State Permit No.

WATER RESOURCES DEPT.
SALEM, OREGON
(Please type or print)
(Do not write above this line)

(1) OWNER:

Name City of Bay City
Address Bay City, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

12 " Diam. from plus 2 ft. to 21 ft. Gage .250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Johnson
Type stainless Model No.
Diam. 10"PS Slot size 100 Set from 20 ft. to 40 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Is a pump test made? Yes No If yes, by whom? driller
Yield: 1000 gal./min. with 3.5 ft. drawdown after 24 hrs.
" " " " "
" " " " "
Pump test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 6 sack mix sacks
How was cement grout placed? by tamping pipe
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Tillamook Driller's well number
SW 1/4 SW 1/4 Section 33 T. 1S R. 9 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 15 ft. below land surface. Date 5/12/80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 50 ft. Depth of completed well 50 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
clay sand brown	0	7	0
clay gravel cobbles gray	7	18	15
sand gravel water gray	18	29	15
clay gravel cobbles brown	29	36	15
sand gravel water brown	36	41	15
clay brown	41	43	15
clay gravel brown	43	50	15

RECEIVED

AUG 5 1980

WATER RESOURCES DEPT
SALEM, OREGON

Work started 4/28/80 19 Completed 5/9/80 19
Date well drilling machine moved off of well 5/12/80 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles R. Peters Date 5/12/80
(Drilling Machine Operator)
Drilling Machine Operator's License No. 574

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Zent Drilling, Inc.
(Person, firm or corporation) (Type or print)
Address 7310 St. Johns Vancouver, Wa. 98665
[Signed] Maxine Zent
(Water Well Contractor)
Contractor's License No. 228 Date 5/13/80, 19.....