WATER WELL REPORT STATE OF OREGON

TILL 857

RECEIVED

JUL 26 1982

WATER RECOURCES DITY. SALEM, ORLCOM

State Well No. $35/10\omega/36$	State Well No.	35/10W/36
---------------------------------	----------------	-----------

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Mike Wilkinson	THO MADON
Address 25875 Hull 1015	County / // // DOR Driller's well number 1/4 1/4 Section 3 6 T. 3 R. / O W.M.
City Claverdale State OR 971/2	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
1 1	
New Well Deepening □ Reconditioning □ Abandon □ If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 30 ft. below land surface, Date 7-1-8
Rotary Air Driven Domestic Industrial Municipal Rotary Mud Dug DIrrigation Test Well Dother D	Artesian pressure lbs. per square inch. Date
Rotary Mud/	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 102 ft. Depth of completed well 102 ft.
(5) CASING INSTALLED: Steel Plastic Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
"Diam. from	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
4"Diam. from 2 ft. to 10.5 ft. Gauge	Clay + Sand Doulder 0 24
(6) PERFORATIONS; Perforated? Yes	green claiptone 24 71
Type of perforator used 5k1/5au	sandstone 7188
Size of perforations 18 in. by in.	claystone 88 102
82 perforations from 2/ ft. to 103 ft.	
perforations from	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes O	
Manufacturer's Name	
Type Model No.	
Diam. Slot Size from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom?	
id: gal/min. with ft. drawdown after hrs.	
Air test gal/min. with drill stem at / / / ft. hrs. Bailer test gal/min. with ft. drawdown after hrs.	
tesian flow g.p.m.	
erature of water Depth artesian flow encountered ft.	
(9) CONSTRUCTION: Special standards: Yes No	Work started 6-2-9 19 S 2 Completed 7-2 19 5 2 Date well drilling machine moved off of well 7-2 19 5 2
Well seal—Material used	The state of the s
Well sealed from land surface to	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Taul (Dickerson Date)-2,19 \$2
Number of sacks of cement used in well seal	Drilling Machine Operator's License No. 549
How was cement grout placed?	
granue grouted	Water Well Contractor's Certification:
Was pump installed?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? No Plugs Depth ft.	
Did any strata contain unusable water? Yes No	Name District Order of the Drilling (Type or print)
Type of Water? depth of strata	Address
Method of sealing strata off	[Signed] Water Well Contractor)
Was well gravel packed? ☐ Yes No Size of gravel:	Contractor's License No. 68 Date 7-2 1982
Constant from / N /	+ LV + LV