## WATER WELL REPORT STATE OF OREGON



## TILL 907 RECEIVED Well No.

PLEASE TYPE or PRINT IN INK
WATER RESOURCES DEPT.

(1) OWNER:	(10) LOCATION OF WELL:
Name Pacific City Water District	County Tillamook Driller's well number
Address P. O. Box 88	4 4 Section 19 T. 4 S R. 10 W. W.M.
City Pacific City, Oregon State 97135	Tax Lot # Lot _ Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
· •	management of the second of th
New Well   Deepening □ Reconditioning □ Abandon □	(11) WATER LEVEL: Completed well.
If abandonment, describe material and procedure in Item 12.	Depth at which water was first found 45
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 7 ft. below land surface. Date $3/1/84$
Rotary Air 🔲 Driven 🗆 Domestic 🗀 Industrial 🗆 Municipal 🕱	Artesian pressure lbs. per square inch. Date
Rotary Mud A Dug	(12) WELL LOG: Diameter of well below casing
	Depth drilled 80 ft. Depth of completed well 80 ft.
(5) CASING INSTALLED: Steel X Plastic Threaded Welded Welded Welded 5	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
8 "Diam from 75 ft. to 80 ft. Gauge .322	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	Fine brown sand 0 37
(6) PERFORATIONS: Perforated? ☐ Yes 🖔 No Type of perforator used	Fine gray-brown sand -wood 37 75  at 67'
Size of perforations in. by in.	Gray silt with some sand 75 80
perforations from ft. to ft.	
ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? XYes \( \square\) No Manufacturer's Name \( \text{LOP Johnson} \)	
Type Stainless Model No	
Diam. $7\frac{1}{2}$ Slot Size • 020. Set from 45ft. to75 ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom? A.M. Jannsen	
d: 138 gal./min. with 30 ft. drawdown after 18 hrs.	
Air test gal./min. with drill stem at ft. hrs.	·······
Bailer test gal/min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started 2/15/84 19 Completed 3/1/84 19
(9) CONSTRUCTION: Special standards: Yes □ NoX□	Date well drilling machine moved off of well 3/1/84 19
Well seal—Material used Cement and 5% gel	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal $1.3\frac{1}{2}$ in.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal $13\frac{1}{2}$ in.	[Signed] Date, 19
Number of sacks of cement used in well seal	Bonded Water Well Constructor Certification:
How was cement grout placed? 19 sacks tremmed into	Bond 390-1672 Issued by: Great American Ins.  Surety Company Name
annular @ 27! back to surface	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was pump installed?	Name A. M. JANNSEN WELL DRILLING CO. INC.
Was a drive shoe used? ☐ Yes XNo Plugs Size: location ft.	(Person, firm or corporation) (Type or print) (Type or print) (Type or print)
Did any strata contain unusable water?   Yes XNo	Address 2107 2-5W IdaIatini valitey iwy. Miona, cac
Type of Water? depth of strata	[Signed]
Method of sealing strata off	Date
Was well gravel packed? X Yes □ No Size of gravel 16. F. S  Gravel placed from	Date, 19, 19
CITATOL PLACED ITOHI	



## Application for Well ID Number

Do not complete if the well already has a Well Identification Number.


I. OWNER INFORMATION
Current Owner Name (please print): Pacific City Joint Water-Sanitary Authority (PCJWSA)
Mailing Address: PO Box 520
City, State, Zip: Pacific City, Oregon 97135
City, State, Zip: Pacific City, Oregon 97135  Mail Well ID Tag to: ✓ SAME AS ABOVE ✓ In Care Of (C/O)
Name & Address: Tony Owen
City, State, Zip:
II. WELL LOCATION INFORMATION (Please fill out as completely as possible)
Township: 4 (North / South) Range: 10 (East / West) Section: 19
Township: 4 (North / South) Range: 10 (East / West) Section: 19  Tax Lot: 300 County Tillamook 1/4 1/4  GPS Coordinates: 45.213109 -123.965048 Nearest: 34005 Cape Kiwanda Dr
GPS Coordinates: 45.213109 -123.965048 Nearest: 34005 Cape Kiwanda Dr
Street Address of Well, City: 1200.2' N 11°3'41" E from W1/4 corner of Section 19, SWNW, T4S, R10W (WM)
If the property had a different street address in the past: Above is POD Location per Water Right
HI CENEDAL WELL INFORMATION (PL. CH
III. GENERAL WELL INFORMATION (Please fill out as completely as possible)  V. SWALON STATE OF THE PROPERTY OF
Use of Well (domestic, irrigation, commercial, industrial, monitoring):  Description:  Domestic. PCJWSA ID - Well #2  Description:  Open Structure   80'   8
Date Well Constructed (or property built): 3/1/1984 Total Well Depth: 80' Casing Diameter: 8"
Owner at time the well was constructed (if known): Pacific City Water District (PCWD)  Other Information: PCWD became PCJWSA July 1, 1998. Well Log #TILL 907.Permit #G-10392. Cert.#80488
Other Information: TOVE Became 1 COVER duly 1, 1990. Well Edg #11EE 907.1 ethil #C=10032. Get.#60400 #15
SUBMITTED BY (please print): Tony Owen
PHONE: 503-965-6636
Send application to: Oregon Water Resources Department 725 Summer St NE, Suite A, Salem, Oregon 97301; or fax to (503) 986-
0902. Applications are processed in the order they are received, and Well ID Numbers are mailed within 4-5 business days.
For Official Use Only by the Oregon Water Resources Department:
Received Date: Well Log Number: Well Identification #:
7-31-15 TILL 907 L-118746
RECEIVED BY OWRD

Last Update: 4/30/14

Well I.D. Number/2

JUL 3 1 2015

WCC





feet meters 200