## WATER WELL REPORT STATE OF OREGON



## RECEIVED AUG 2 1 1981 State Well No.

WATER RESOURCES DEPTermit No. SALEM, OREGON

1) OWNER:	(10) LOCATION OF WELL:	
Name WI-NE-MA Christian Camp, INC.	County Tillamook Driller's well number 2383	
address 5195 Winema Rd.	40 50	W.M.
Sity Cloverdale, Oregon 97112 State	Tax Lot # Lot Blk Subdivision	-
2) TYPE OF WORK (check):	Address at well location:	
lew Well ☑ Deepening □ Reconditioning □ Abandon □		
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
	Depth at which water was first found 84	ft.
	Static level 18 ft. below land surface. Date 8/1	
otary Air 💢 Driven 🗆 Domestic 🗀 Industrial 🗀 Municipal 💢 Gatary Mud 🗇 Dug 🖂 Irrigation 🖂 Test Well 🖂 Other 🖂	Artesian pressure lbs. per square inch. Date	
□ Bored □ Thermal: Withdrawal □ Reinjection □	(12) WELL LOG: Diameter of well below casing	E45444
5) CASING INSTALLED: Steel N Plastic	Depth drilled 160 ft. Depth of completed well 160	ft.
Threaded □ Welded ₩	Formation: Describe color, texture, grain size and structure of materials; and	
	thickness and nature of each stratum and aquifer penetrated, with at least one of for each change of formation. Report each change in position of Static Water I	
"Diam. from	and indicate principal water-bearing strata.	
LINER INSTALLED:	MATERIAL From To SW	nL .
4"Diam. from0	Topsoil C 4	
6) PERFORATIONS: Perforated? XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	Black Basalt 4 13	
ype of perforator used skilsaw	Brokkn Rock 13 32	
ize of perforations $5$ in. by $1/8$ in.	Black Basalt 32 43	
60 perforations from 81 ft. to 140 ft.	Browkn Rock 43 84	
perforations from ft. to ft.	Blue Shale, broken, w.b. 84 140	
perforations from	Blue Shale 140 160	
7) SCREENS: Well screen installed?   Yes   No		
Ianufacturer's Name		
ype Model No		
Slot Size Set from ft. to ft.		
hiam. Slot Size Set from ft. to ft.		
8) WELL TESTS:  Drawdown is amount water level is lowered below static level		
is a pump test made?    Yes    No If yes, by whom?		
eld: gal/min. with ft. drawdown after hrs.		
ir test 14 gal/min. with drill stem at 159ft. 2 hrs.		
ealer test gal/min. with ft. drawdown after hrs.		
tesian flow g.p.m.		
Emperature of water Depth artesian flow encountered ft.	7/20/24 22 22 22 22 22 22 22 22 22 22 22 22 2	
9) CONSTRUCTION: Special standards: Yes \( \text{No } \frac{\text{Y}}{2} \)	Work started 7/29/81 19 Completed 8/1/81 18 Date well drilling machine moved off of well 8/1/81 18	
Vell seal—Material used Portland. Cement. & 5% bentonite		<del></del>
Vell sealed from land surface to40	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision. Materials	
riameter of well bore to bottom of seal10 in.	and information reported above are true to my best knowledge and hel	
liameter of well bore below seal	[Signed] Date 8/3/81, 19.	
Sumber of sacks of cement used in well seal11	Drilling Machine Operator's License No752	
low was cement grout placed? pumpedinthruconductorpipe	Diffing Machine Operator's Intense 140	
The state of the s	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is true the best of my knowledge and belief.	ie to
/as pump installed?	Name WILLAMETTE DRILLING CO.	
Vas a drive shoe used? X Yes □ No Plugs Size: location ft.  Vid any strata contain unusable water? □ Yes ▼ No	(Person, firm or corporation) (Type or print)	7000
ype of Water? depth of strata	Address 7365 O Neil Rd. N.E. Salem, Oregon 9	<u>/3</u> 03
Lethod of sealing strata off	[Signed] Pallas K. Day. (Water Well Confractor)	
Vas well gravel packed? ☐ Yes No Size of gravel:	(Water Well Confractor)	
ravel placed from ft to ft	Contractor's License No. 561 Date 8/3/81 ,19	