The original and first opper of this report are to be APR 2 6 1971

STATE OF OREGON

UMAT 1046

						OC
		211	122	-2	K	-1.
Well	No.	E 18		- Apr.	0	

STATE ENGINEER, SALEM OFFICE NO. 171 EFR (Please type or print) within 30 days from End date! EFR (Please type or print) of well completion SALEM. OR SOLO NO not write above this line)

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL: 45				
Name Leonard Wells	County Umatilla Driller's well number Number 6				
Address 1102 SW 30th, Pendleton, Oregon	5W 14 NW 14 Section 28 T. 2N R. 33 E W.M.				
	Bearing and distance from section or subdivision corner				
(2) TYPE OF WORK (check):					
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐					
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 59 ft.				
Rotary Driven Domestic M Industrial Municipal Domestic M Industrial Municipal Domestic M Industrial D Industri	Static level 17 ft. below land surface. Date 3/17/71				
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date				
CASING INSTALLED:	(12) WELL LOG: Diameter of well below casing				
Lype of perforator used	MATERIAL From To SWL				
Size of perforations in. by in.	Soil. Brown 0 3				
perforations from ft. to ft.	Claystone, white 3 6				
perforations from ft. to ft.	Gravel, Coarse 6 21				
perforations from ft. to ft.	Clay, Brown, Sticky 21 42				
(E) CODINENC.	Basalt, Brown 42 59				
(7) SCREENS: Well screen installed? ☐ Yes ⋈ No	Broken Basalt, Blk., Homey-				
Manufacturer's Name	combed & Brown 59 77 WATER				
Type Model No.	Hard, Gray, Basalt 77 95				
Diam. Slot size Set from ft. to ft.					
Diam. Slot size Set from ft. to ft.					
(8) WELL TESTS: Drawdown is amount water level is lowered below static level					
Was a pump test made? Yes No If yes, by whom?					
Yield: 90 gal./min. with 15 ft. drawdown after hrs.					
AIR TEST " "					
" " " " " " " " " " " " " " " " " " "	l				
Bailer test gal./min. with ft. drawdown after hrs.					
Artesian flow g.p.m.					
perature of water Depth artesian flow encountered ft.	Work started 3/16/ 1971 Completed 3/17/ 1971				
(9) CONSTRUCTION:	Date well drilling machine moved off of well March 17 1971				
Well seal—Material usedCement	Drilling Machine Operator's Certification:				
Well sealed from land surface to 31 ft. & 59 ft. ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my				
Diameter of well bore to bottom of seal 14" & 9 in.	best knowledge and belief.				
Diameter of well bore below seal in.	[Signed] Om Pany DateMarch 171971				
Number of sacks of cement used in well seal 13 & 14 sacks	(Drilling Machine Operator)				
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No. 640				
Brand name of bentonite	Water Well Contractor's Certification:				
Number of pounds of bentonite per 100 gallons	•				
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.	Name PROJECT: Corporation				
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print) Address 24 North Second, WallaWalla, Wn.				
Type of water? depth of strata	Address 24 North Second, Wallawalla, Wil.				
Method of sealing strata off	[Signed] Vallflyor				
Was well gravel packed? 🗍 Yes 🗷 No Size of gravel:	(Water Well Contractor)				
Gravel placed from ft. to ft.	Contractor's License No. 512 Date April 12th 71				

