

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
WATER WELL REPORT
FEB 8 - 1972
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

UMAT
106
G-5701

State Well No. 1132-21
State Permit No.

STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

(1) OWNER:

Name Maryl F. + Flora J. Chapman
Address P.O. Box 303
Felton Rock, Oregon 97868

(2) TYPE OF WORK (check)

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 44 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 300 gal./min. with 68 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 44 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 14 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? surface depth of strata 15
Method of sealing strata off cement
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 1/4 Section 21 T. 18. R. 32 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 140 ft. below land surface. Date 1-31-72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 260 ft. Depth of completed well 260 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Boulders	1	20	
Clay & gravel	20	31	
Rock, hard, brown	31	50	Water bearing at 40 ft.
Rock, red & yellow claystone	50	71	
Rock, light brown	70	85	
Rock, med. black	85	100	
Basalt, med.	100	170	
Basalt	170	190	
Basalt gray hard	190	210	
Rock, light brown	210	240	Water bearing
Rock, red	240	260	Water bearing

Work started 12-17 1971 Completed 1-31 1972
Date well drilling machine moved off of well 1-31 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Troy Griffin Date 1-31, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TROY GRIFFIN
(Person, firm or corporation) (Type or print)

Address 925 HERMISTON AVE. HERMISTON ORE.

[Signed] Troy Griffin
(Water Well Contractor)

Contractor's License No. 65 Date 1-31, 1972