NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 18 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

UMAT 1146

State Well No. 2N/35-5ad

State Permit No. G 5154

(1) OWNER:
Name D.A. Davis
Address P.O. Box 62
Adams, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 228 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level ft. below land surface Date
Artesian pressure 3-4 lbs. per square inch Date 6/11/69

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 75 g.p.m. Date June 10, 1969
Temperature of water 58 Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:
Well seal—Material used Bentonite, pressure grout
Depth of seal 22' casing driven ft.
Diameter of well bore to bottom of seal 6 in.
Were any loose strata cemented off? ☒ Yes ☐ No Depth 0-22'
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Umatilla Driller's well number
S.E. ¼ N.E. ¼ Section 5 T. 2N R. 35 E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 90' ft. Depth of completed well 90' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Boulders, gravel coarse	0	22	
Basalt, black	22	82	
Porous rock, red water	82	90	

Work started June 10 1969 Completed June 10 1969
Date well drilling machine moved off of well June 11 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Don Parry (Drilling Machine Operator) Date June 11 1969
Drilling Machine Operator's License No. 640

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Project Corporation (Person, firm or corporation) (Type or print)
Address 1 South Second Walla Walla, Wash
[Signed] Cale Allwood (Water Well Contractor)
Contractor's License No. 512 Date 7/14/69, 19

(USE ADDITIONAL SHEETS IF NECESSARY)