NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

UMAT 1148

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. #44 2N/35-5F

State Permit No. 330

SEP 14 1964
STATE ENGINEER
SALEM, OREGON

(1) OWNER:
Name Arnold Lavadour Sr.
Address Adams, Oregon

(2) LOCATION OF WELL:
County Umatilla Driller's well number 44
SE ¼ NW ¼ Section 5 T. 2 R. 35 W.M.
Bearing and distance from section or subdivision corner
Williamette Meridian in Oregon

(3) TYPE OF WORK (check):
New Well XX Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic X Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable X Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
6" Diam. from 1 ft. to 18 ft. Gage 0.28
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☐ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement & Grout
Depth of seal 19.5 ft. Was a packer used? No
Diameter of well bore to bottom of seal 6 in.
Were any loose strata cemented off? ☐ Yes X No Depth
Was a drive shoe used? X Yes ☐ No
Was well gravel packed? ☐ Yes XX No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? X Yes ☐ No
Type of water? Surface depth of strata
Method of sealing strata off 13'

(10) WATER LEVELS:
Static level 18 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 4 gal./min. with 63 ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well below casing
Depth drilled 60 ft. Depth of completed well 60 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Silt	1	13
Static Water	[illegible]	18
Brown Rock	33	41
Red Rock	41	50
Black Rock	50	53
Water Baildown	53	60
Red Rock	60	60

19.5 total casing with shoe casing cemented in 5'

Work started 5-4-64 19 Completed 6-17-64 19
Date well drilling machine moved off of well 6-17-64 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Haden Drilling Co. (Person, firm or corporation) (Type or print)
Address 4304 W. Court, Pasco, Washington
Drilling Machine Operator's License No. 331
[Signed] Floyd A. Haden (Water Well Contractor)
Contractor's License No. 409 Date 9-3-64, 19

(USE ADDITIONAL SHEETS IF NECESSARY)