

RECEIVED

NC

UMAT 1173

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER

WATER WELL REPORT

State Well No. 3N/28-1 H(1)

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name State Highway Commission Address Hermiston, Oregon

(2) LOCATION OF WELL:

County Umatilla Driller's well number 1/4 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner Stanfield Rest Area Eastbound lane Mile Post 185.5

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded [] Welded [X] 10" Diam. from 0 ft. to 64 ft. Gage .250 6" Diam. from 0 ft. to 76 ft. Gage .250

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Depth of seal 7.6ft. Was a packer used? no Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 6-27-66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Driller Yield: 50 gal./min. with 46 ft. drawdown after 4 hrs.

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 135 ft. Depth of completed well 135 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Sandy Soil, Sand and gravel, Clay Gravel, Brown Shale Rock, Brown Sandy clay, White Sand, Black Basalt Rock, Brown Sandstone, Black Rock Medium, Gray Rock Hard, Brown Sand Rock, Brown Rock Medium, Brown Clay Stone.

Work started 6-7 19 66 Completed 6-27 1966 Date well drilling machine moved off of well 6-28 1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ben Dreyer Drilling Contractor (Person, firm or corporation) (Type or print)

Address Rt. 1, Box 225 Hermiston, Oregon

Drilling Machine Operator's License No. 7

[Signed] Ben Dreyer (Water Well Contractor)

Contractor's License No. 12 Date June 27, 1966