

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMAT
1215

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

MAY 25 1976

State Well No. 3N/28E-26 23

(Do not write above this line) WATER RESOURCES DEPT. No. LEL#1

SALEM, OREGON

(1) OWNER:

Name L & L FARMS INC.
Address 807 W. TAMARACK
HERMISTON, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
16" Diam. from +1 ft. to -49 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Type
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom?
Yield: 2000+ gal./min. with ft. drawdown after hrs.
AIR LIFT " " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow NONE g.p.m.
Temperature of water 66 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used NEAT CEMENT
Well sealed from land surface to 49 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 50 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County TAMATILLA Driller's well number 04-76
SW 1/4 SE 1/4 Section 26 T. 3N R. 28 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 306 ft.
Static level 330 ft. below land surface. Date 4-20-76
Artesian pressure NONE lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 16" to 10 1/2"
Depth drilled 1,012 ft. Depth of completed well 1,012 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SILT SAND	0	14	
GRAVEL CLAY	14	30	
MED. HARD BROWN BASALT	30	65	
HARD GREY	65	85	
MED. HARD GREY	85	127	
SOFT GREY	127	135	
HARD GREY	135	256	
MED. HARD GREY	256	281	
HARD GREY	281	306	
SOFT, BROKEN, SEAMS	306	331	WATER
HARD GREY	331	452	
BROKEN GREY w/soapstone	452	456	WATER
HARD GREY BASALT	456	538	
BROKEN w/SEAMS	538	638	WATER
HARD GREY	638	888	
BROKEN w/soapstone	888	913	WATER
HARD GREY BASALT	913	913	
BROKEN BASALT	913	988	WATER
HARD GREY BASALT	988	1012	

Work started 2-26 19 76 Completed 4-20 19 76
Date well drilling machine moved off of well 4-24 19 76

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Correll A. Wallace Date 5-23, 19 76
(Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name WALLACE WELL DRG. CO.
(Person, firm or corporation) (Type or print)

Address Box 792 PENDELTON

[Signed] Correll A. Wallace
(Water Well Contractor)

Contractor's License No. 583 Date 5-23, 19 76