

WATER WELL REPORT
STATE OF OREGON

UMAT
1246

RECEIVED

AUG 10 1983

State Well No.

3W/29E-5ab

PLEASE TYPE or PRINT IN INK

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:
Name Ray Brady
Address Bx 601
City Stanfield State Or. 97825

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(5) CASING INSTALLED: Steel Plastic
Threaded Welded
8" Diam. from 71 ft. to 24 ft. Gauge 250

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Field: gal./min. with ft. drawdown after hrs.
Air test 100 gal./min. with drill stem at 50 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 8 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 20 sacks
How was cement grout placed? Pressure grouted
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Umatilla Driller's well number
NW 1/4 NE 1/4 Section 5 T. 3N R. 29 W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: Stanfield, Or. 97875

(11) WATER LEVEL: Completed well.
Depth at which water was first found 21 ft.
Static level 4 ft. below land surface. Date 7-13-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Silty soil	0	2	
Light brown clay	2	12	
Caliche	12	14	
Fine sand	14	21	
Gravel	21	26	WB
Clay	26	40	
Gray basalt	40	50	

Work started 7-11 1983 Completed 7-13 1983
Date well drilling machine moved off of well 7-13 1983

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification
Bond SB 36090 Issued by: Oregon Automobile Ins. Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Wallace Drilling (Person, firm or corporation) (Type or print)
Address 1307 SW 23rd, Pendleton, Or. 97801
[Signed] Patrick C. Wallace Water Well Constructor
Date 7-20, 1983

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690