

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMAT
1279
NE
#1

WATER WELL REPORT

RECEIVED

SESE
3N/29E-7062
G-8126
6-8772 App

STATE OF OREGON
(Please type or print)

JUL 14 1978

(Do not write above this line)

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name DANNY COX + KENNETH BATTY
Address R.R. #1
STANFIELD, OR.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
14" Diam. from 0 ft. to 150 ft. Gage 250
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Est. 2,000 G.P.M. AIR LIFT "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used NEAT CEMENT
Well sealed from land surface to 150 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 14 in.
Number of sacks of cement used in well seal 70 sacks
How was cement grout placed?
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 03-78
NE 1/4 NE 1/4 Section 10 T. 3N. R. 29E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 343 ft.
Static level 337 ft. below land surface. Date 6-10-78
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8" BELLW
Depth drilled 1360 ft. Depth of completed well 1360 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
3 1/2 ft. Soil	0	10	
COBBLES	10	15	
BROKEN GREY BRN	15	135	
HARD " "	135	165	
MED. " "	165	343	
BROKEN " "	343	350	water
HARD " "	350	516	
BROWN " "	516	530	water
MED. HARD " "	530	880	
MED. SOFT " "	880	1035	
HARD " "	1035	1065	
BROKEN " "	1065	1116	water
MED. HARD " "	1116	1322	
HARD " "	1322	1340	
BROKEN " "	1340	1360	

Work started 5-12 1978 Completed 6-10 1978
Date well drilling machine moved off of well 6-10 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ed Wallace Date 7-7, 1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Wallace Webb Drilling Co.
(Person, firm or corporation) (Type or print)
Address PENDLETON, OR. 97801
[Signed] Ed Wallace
(Water Well Contractor)
Contractor's License No. 583 Date 7-7, 1978