NOTICE TO WATER WELL CONTRACTOR The original and first copy

of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 9 within 30 days from the date of well completion.

WATER WELL REPORT EIVED 12 3n-29-24

STATE OF OREGONFEB 3 - 1976 State Well No.

(Please type or print) RESOURCES DEPT. (Do not write above this line) SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name Kenny Cappinger	County Umatilla Driller's well number
Address R.R.	NW 1/4 NE 1/4 Section 24 T. 3N R. 29 W.M.
Echo, oregon	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 133 ft.
Rotary Driven Domestic Industrial Municipal	Static level 137 ft. below land surface. Date /- 2/- 7/4
Cable	Artesian pressure NoNE lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing 10 is.
"Diam. from ft. to ft. Gage ft. Gage	Depth drilled 3/8 ft. Depth of completed well 3/8 ft.
"Diam from ft. to ft. Gage ft. Gage	Formation: Describe color, texture, grain size and structure of materials;
(6) PERFORATIONS: Perforated? Yes No	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Silt sails 1 16
perforations from ft. to ft.	1000 harst. 16 30
perforations from ft. to ft.	mile hard grow 30 153 1sture
perforations from ft. to ft.	brokens brown Lasel 53 18/ water/
	med, Karlygrey basalt 181 222 +
(7) SCREENS: Well screen installed? Yes No	broken obaselt 225 235 hearing
Manufacturer's Name	forsalasolt 235 250
Type Model No	broken w/ grazel 250 255 fearing
Diam Slot size	sould hard basalt 255 290
Diam Slot size Set from ft. to ft.	broken W/Sand, grave 290 3/8 Learning
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level PARMORE	
Was a pump test made? Yes No If yes, by whom? SERVICE	
gal./min. with 0 ft. drawdown after 3 hrs.	
" " "	
<i>n n</i>	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	7
perature of water 2 Depth artesian flow encountered MONE ft.	Work started JAN, 6 1976 Completed JAN, 2/ 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well Jan 18 19 76
Well seal-Material used Neat Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to 38 ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge and belief
Diameter of well bore below seal	Signed Werell W. Wallace Date 1-2/ 1976
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No.
Brand name of bentonite	TYTAL TYTAL Contractors Contifications
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Yes No Plugs Size: location ft.	Name WALLACE WELL DRILLING CO.
Did any strata contain unusable water? Yes No	(Berson, firm or corporation) (Type or print)
Type of water? depth of strata	Address 1, 150x 192 FNDLETON, OR
Method of sealing strata off	[Signed] Currell W. Waller
Was well gravel packed? [] Yes No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 583 Date