NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

AMENDED

WELL LOG

## WATER WELL RRECEIVED

STATE OF OREGON

WATER RESOURCES DEPARTMENT. UMAT SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print) JAN 18 1978 (Do not write above this line) RESOURCES DEPT.

State Permit No.

	SALEM OREGON
(1) OWNER;	(10) LOCATION OF WELL:
(1) OWNER: Name WARREN G. BOYER	County ZIMATILLIA Driller's well number 035-77
Address Box 171	Contax & NE 14 Section 30 T. 3 N R. 29 E, W.M.
ECHO, URE,	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening Reconditioning Abandon	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found
Rotary Driven Domestic Industrial Municipal	Static level 4/5 ft. below land surface. Date ///30/
Cable	Artesian pressure lbs. per square inch. Date
CACCALC TAXONALLED	2"
SASING INSTALLED: Threaded □ Welded □	(12) WELL LOG: Diameter of well below casing
	Depth drilled //00 ft. Depth of completed well //00 ft.
" Diam. from	Formation: Describe color, texture, grain size and structure of materials;
Diam. from	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated?   Yes   No.	position of Static Water Level and indicate principal water-bearing strata.
_ype of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	MED. HARD GREV VAIZ 1081
perforations from tt. to tt.	SOFT KED BASALT 108/ 1097 water
perforations from	HARD GREY BASALT 1097 1100
perforations from ft. to ft.	
(E) CODERNO.	
(7) SCREENS: Well screen installed?   Yes   No	
Manufacturer's Name	10-
TypeModel No	DEEPENED FROM 1012 FT TO 1100 F
Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	YUMP CHAMBER DEEPENED 145 FT.
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level	
Was a pump test made? Yes No If yes, by whom?	
Yield: 1560 gal./min. with 10 ft. drawdown after 4 hrs.	
, , , , , , , , , , , , , , , , , , , ,	
, , , , , , , , , , , , , , , , , , , ,	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
verature of water Depth artesian flow encountered ft.	Work started ///29 19 77 Completed ///30 19/7
(9) CONSTRUCTION:	Date well drilling machine moved off of well ///30 19 7
• •	Drilling Machine Operator's Certification:
Well seal—Material used  Well sealed from land surface toft.	This well was constructed under my direct supervision.
	Materials used and information reported above are true to my
Diameter of well bore to bottom of seal in.  Diameter of well bore below seal in.	best knowledge and belief.
Number of sacks of cement used in well seal sacks	[Signed] Date 19, 19
How was cement grout placed?	Drilling Machine Operator's License No
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.	I INDIVICE INTELL NOIS US
Did any strata contain unusable water?   Yes   No	Name (Egron) firm or corporation) (Type or print)
Type of water? depth of strata	Address PENALETON, ORE,
Method of sealing strata off	1 Miller
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 583 Date 12/30 197
•	