NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

filed with the

(Please type or WAITER RESOURCES DEPT Permit No. ...
(Do not write above this lineALEM, OREGON

WATER WELL REPORT DECI 8 1975 State Well No. 3N/30E-9

(1) OWNER:	(10) LOCATION OF WELL:
Name Lean Revol	County UMETILLA Driller's well number 15-75
Address Cala ON	NW 14 SW 14 Section 9 T. 3N R. 30 E W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening	<u>.</u>
If abandonment, describe material and procedure in Item 12.	(11) WARDD LEWEL. Completed mall
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 120 ft.
Cable	Static level 98 ft. below land surface. Date 60-8-75
Dug Bored Firigation Test Well Other	Artesian pressure ————————————————————————————————————
CASING INSTALLED: Threaded Welded O "Diam from ft to 22.5 ft Gage 250 "Diam from ft to ft Gage "Diam from ft to ft Gage PERFORATIONS: Perforated? Yes 2-No.	(12) WELL LOG: Diameter of well below casing
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	BASALT BLECK 380 592
perforations from	11 ReD 592 598
perforations from ft. to ft.	
perforations from ft. to ft.	<u> </u>
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	
Manufacturer's Name	EXISTING WELL
Type Model No.	W29 380' Deep
Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? IP Yes □ No If yes, by whom? FERMER €	4
Yield: 300 gal./min. with 150 ft. drawdown after / hrs.	
" " " "	
" " " "	
	<u> </u>
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m. perature of water & Depth artesian flow encountered ft.	
	Work started 9-24 1975 Completed 10-8 1975
(9) CONSTRUCTION:	Date well drilling machine moved off of well 1975
Well seal-Material used PORTLEND COMENT	Drilling Machine Operator's Certification:
Well sealed from land surface to 22 /2 ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Date 10-8, 19.75
Number of sacks of cement used in well sealsacks	1 034
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License-No
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Yes 140 Plugs Size: location ft.	Name Yang Burd well dulling
Did any strata contain unusable water? Tyes 12 No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Po BOX 917 Pendlator or
Method of sealing strata off	[Signed] Sung Bund
Was well gravel packed? Tyes 480 Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 544 Date 10-8 , 19.73