NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORTS | V E Date Well No. 15

(Please type or print) OCT 201976 State Permit No. (Do not write above this line)
VATER RESOURCES DEPT

(1) OWNER:	(10) LOCATION OF WELL:
Name WAYNE PLATT	County UMATIBLA Driller's well number 028-76
Address STAR RT.	NW 14 NN 14 Section /2 T. 15, R. 33 E. W.M.
PILOT ROCK, ORE.	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 38 ft.
Rotary Driven Domestic Industrial Municipal	Static level 53 ft. below land surface. Date 10-5-76
Cable	Artesian pressure NOVE lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing 8
10 " Diam. from 0 ft. to 21 ft. Gage 1250	Depth drilled 3/5 ft. Depth of completed well 3/5 ft.
ft. Gageft.	+=
" Diam, from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
(6) PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	soil = 02
perforations from ft. to ft.	BROVEN GREV BASAGE 2 6
perforations fromft. toft.	BROWN 111, 6 55
perforations from	GREV BASALT WISEAMS 55 126 WATER
	BROWN BASALT 126 132
(7) SCREENS: Well screen installed? Yes No	HARD GREY BASALT 132 209
Manufacturer's Name	BRONEN BROWN 209 245 WATER
Type Model No	GREY BASAUT 245 290
Diam. Slot size Set from ft. to ft.	BROKEN GREY OF SOAPSTON 290 315 WATER
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom?	
"AIR LIFT EST, 200 GPM + "	, g zeregia
"HIR LIFT EST, 200 GPM 1"	
Bailer test gal./min. with ft. drawdown after hrs.	
sian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started /6-4 1975 Completed /6-3 19 76
(9) CONSTRUCTION:	Date well drilling machine moved off of well 1976
Well seal-Material used NEAT CEMENT	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Cierell Mallall Date 10-10, 1976
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator) Drilling Machine Operator's License No.
Number of sacks of bentonite used in well seal sacks	Diming Wachine Operator's License No.
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals.	true to the best of my knowledge and belief
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft. Did any strata contain unusable water? ☐ Yes ☑ No	Name WALDACE WELL, LIELG. Co. (Person, firm or corporation) / (Type or print)
	Address TENDLE TON, OPE, 9788/
Type of water? depth of strata	Con II landlan
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? Yes No Size of gravel:	223 11.10 11/
Gravel placed from ft. to ft.	Contractor's License No. Date