

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
NOV 14 1967
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

UMAT
1350

G-6359

State Well No. 3N/30-9
State Permit No. _____

(1) OWNER:

Name Ralph Reese
Address ~~1015 SW. Fraser~~
Echo Ore.

(2) LOCATION OF WELL:

County UMATILLA Driller's well number _____
1/4 Section 9 T. 3N R. 30 E W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal _____
Depth of seal 18 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 8.5 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 90 ft. below land surface Date 4/20/67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" Air Tested 1.75 gal per min

Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 60 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____ 6"

Depth drilled 379 ft. Depth of completed well 379 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
rock Gray / ^{green} / ^{black} spots	304	330
rock Gray	330	356
rock black porous	356	367
rock Gray	367	379

Work started 4/11 1967 Completed 4/19 1967
Date well drilling machine moved off of well April 20 1967

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ray T. French
(Person, firm or corporation) (Type or print)
Address 1015 SW. Fraser
Drilling Machine Operator's License No. 129
[Signed] Ray T. French
(Water Well Contractor)
Contractor's License No. 107 Date Apr 21, 1967