

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
APR 19 1967
STATE ENGINEER
SALEM OREGON
WATER WELL REPORT
(Please type or print)

UMAT
1351

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

State Well No. 3N/30-9
State Permit No. _____

(1) OWNER:

Name Ralph Reese
Address Echo Ore

(2) LOCATION OF WELL:

County Umatilla Driller's well number E
1/4 Section 9 T. 3N R. 30 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 2.0 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by _____ in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
in. Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Betonite
Depth of seal 1.8 ft. Was a packer used? N.O.
Diameter of well bore to bottom of seal 8.5 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 92 ft. below land surface Date 3, 25, 67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 100 gal./min. with 230 ft. drawdown after 4 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 52° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 304 ft. Depth of completed well 304 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
light Brown C/AY Soil	0	12
red rock	12	16
red + black rock	16	20
Grey rock	20	24
Broken rock	24	35
Grey rock	35	100
Broken Grey rock	100	108
red rock	108	124
black rock	124	136
water bearing porous black rock	136	179
red rock, water bearing	179	185
Black rock / clay seams	185	231
Brown Broken rock	231	240
Black rock water bearing	240	243
red porous rock	243	275
water bearing		
Grey rock	275	304

Work started Feb 20 1967 Completed Feb 25 1967
Date well drilling machine moved off of well Feb 25 1967

(13) PUMP:

Manufacturer's Name none yet
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Roy T. French (Type or print)
(Person, firm or corporation)

Address 1015 S.W. FRABER

Drilling Machine Operator's License No. 129

[Signed] Roy T. French
(Water Well Contractor)

Contractor's License No. 107 Date 3, 1, 1967