

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

UMAT
 138

PLEASE TYPE or PRINT IN INK

RECEIVED

JUL 29 1988

19/32E-1dd

WATER RESOURCES DEPT. (for official use only)

(1) OWNER:

Name Ernie Farris
 Address 1812 SW 45th
 City Pendleton State OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Thermal:
 Other: Withdrawal ReInjection
 Piezometric Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 12" Diam. from 7.2 ft. to 28.9 ft. Gauge 2.50
 " Diam. from ft. to ft. Gauge

LINER INSTALLED:

Steel Plastic
 Threaded Welded
 " Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot Size Set from ft. to ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 id: gal./min. with ft. drawdown after hrs.
 Air test 60 gal./min. with drill stem at 130 ft. 1 hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water 58° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used Portland cement
 Well sealed from land surface to 28' ft.
 Diameter of well bore to bottom of seal 15 in.
 Diameter of well bore below seal 12 in.
 Amount of sealing material 22 sacks pounds
 How was cement grout placed? tremie
 Was pump installed? NO Type HP Depth ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County umatilla SE 1/4 SE 1/4 of Section 1 of
 Township 15 Range 92 E WM.
 (Township is North or South) (Range is East or West)
 Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

Start card 1209

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 103 ft.
 Static level 36 ft. below land surface. Date 7-17-88
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12"
 Depth drilled 130 ft. Depth of completed well 130 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	10	
Basalt			
Brown	10	18	
Black	18	35	
Brown	35	62	
Brown	62	68	
Black	68	73	
Brown	73	101	
GREY	101	103	
fractured zone	103	105	
Brown	105	112	
Grey	112	114	
GREY BROWN	114	130	

Date work started 7-12-88/completed 7-17-88
 Date well drilling machine moved off of well 7-17-88 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jerry Burd Date 7-17, 19 88

(bonded) Water Well Constructor Certification:

Bond (number) Issued by: (Surety Company Name)
 On behalf of LARRY BORD WELL DRILLING INC.
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Jerry Burd (Water Well Constructor)

(Dated) 7-17-88

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.