

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMAT
1428

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

APR 19 1978

State Well No.

3N/34E-300

WATER RESOURCES DEPT.

Permit No.

G-7874

SALEM, OREGON

(1) OWNER:

Name SHELDON LIEBELLEN
Address ADAMS ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
16" Diam. from +2 ft. to -18 ft. Gage -250
12" Diam. from +2 ft. to -560 ft. Gage -250
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? FARMORE

Yield: 1500 gal./min. with 162 ft. drawdown after 8 hrs.

Bailer test gal./min. with " ft. drawdown after " hrs.

Artesian flow g.p.m.

Temperature of water 66° Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 22 in.

Diameter of well bore below seal 14 3/4 in. TO 560'

Number of sacks of cement used in well seal 12 SACKS sacks

How was cement grout placed? GRAVITY

DRIVE SHOE ON 12 1/4"

Was a drive shoe used? Yes No Plugs " Size: location " ft.

Did any strata contain unusable water? Yes No

Type of water? " depth of strata "

Method of sealing strata off "

Was well gravel packed? Yes No Size of gravel: "

Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number

SE 1/4 SE 1/4 Section 3 T. 3N R. 34E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 320 ft.

Static level 278 ft. below land surface. Date 4-10-78

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12 1/4

Depth drilled 980 ft. Depth of completed well 980 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	11	
BASALT BLACK	11	320	
" BRN w/ Talc	320	330	506
" BLACK	330	460	
" BRN w/ Talc	460	470	300G
" BLK	470	610	
" BLK w Talc	610	748	170 LBS
" BLK w Talc	748	800	
" GREY	800	815	215 LBS
" BLK w Red	815	820	222 LBS
" BLK	820	895	
" BK BLU + Red	895	930	240 LBS
" BK	930	955	
" BK w BLUE Talc	955	972	260 LBS
" GREY SOFT	972	980	

Work started 3-7 1978 Completed 4-10 1978

Date well drilling machine moved off of well 4-10 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jay Burd Date 4-10, 1978
(Drilling Machine Operator)

Drilling Machine Operator's License No. 933

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Jay Burd Well Drilling
(Person, firm or corporation) (Type or print)

Address 5543 S.W. Douglas Pk Road

[Signed] Jay Burd
(Water Well Contractor)

Contractor's License No. 544 Date 4-10, 1978