

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
WATER WELL REPORT
UMAT
1438
JUL 11 77
SE, NE 77

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.
WATER RESOURCES DEPARTMENT
SALEM, OREGON

State Well No. 3N/31E-622
State Permit No. _____

OCT 10 1977

(1) OWNER:
Name GILBERT BOYER, SR.
Address RT#1 BOX 443
PENDLETON, ORE.

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED:
8" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:
Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
EST. 100 GPM AIR LIFT " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used HEAT CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? _____

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County Tumattilla Driller's well number 062-77
NE 1/4 NE 1/4 Section 6 T. 31. R. 34 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 91 ft.
Static level 90 ft. below land surface. Date 9-4-77
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 515 ft. Depth of completed well 515 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	14	
GREY BASALT	14	32	
BROWN BASALT	32	46	
SOFT BROWN "	46	59	
HARD GREY "	59	77	
SOFT BROKEN "	77	91	
" GREY "	91	104	water
GREY "	104	150	
SOFT BROWN w/soapstone	150	157	
GREY "	157	231	
BROKEN "	231	249	water
GREY "	249	335	
BROKEN GREY "	335	462	water
GREY "	462	501	
MED. HARD GREY "	501	515	

Work started 8-31 19 77 Completed 9-3 19 77
Date well drilling machine moved off of well 9-4 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] W. Wallace Date 9-4, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WALLACE WELLS DRUG
(Person, firm or corporation) (Type or print)
Address Pendleton, Ore.
[Signed] W. Wallace
(Water Well Contractor)
Contractor's License No. 583 Date 9-4, 19 77